



congerlpgas.com

INVOICE / WORK ORDER NO.

120809

146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306 S. Main St.
Sylvester, GA 31791
(229) 776-7336

604-B N. Broadfoot Blvd.
Vidalia, GA 30474
(912) 537-8722

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

2310-B Highway 84 W
Valdosta, GA 31602
(229) 469-4250

NAME Bozeman, Grocery RT# _____ RT. SEQ. _____ ACCT # 02-21145 DATE 2-4-2025 INT JS

MAILING ADDRESS _____ CO. _____ CITY _____

ADDRESS 2223 GA HWY 313 APT/LOT NO. _____

CITY _____ STATE _____ ZIP CODE _____

NEW CUSTOMER INFORMATION

S.S. NO. _____ DELV _____
HOME PH _____ RENT _____
WORK PH _____ CREDIT _____
LITE PILOT _____ PG _____
EMPLOYER _____
DR. _____ USE _____ LEASE _____

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____

email: _____

cell # _____

PAY BILL ONLINE @congerlpgas.com

DIRECTIONS:

Run line to water heater

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
<u>set</u>	<u>250</u>	<u>1535628</u>	<u>209a</u>	<u>@2.999</u>	MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
<u>31"</u>	<u>3/8 copper</u>			<u>3.95</u>	<u>122.45</u>
	<u>pipe + fittings</u>				<u>45.95</u>
	<u>B4 regulator</u>				<u>59.95</u>
<u>4</u>	<u>1/2 cutoffs</u>			<u>19.95</u>	<u>79.80</u>
<u>2</u>	<u>ACME x 1/4</u>			<u>42.99</u>	<u>85.98</u>
<u>1</u>	<u>AL 75c</u>	<u>AL75c</u>	<u>ALCA-036605</u>	<u>(X14)</u>	<u>999.25</u>
	<u>settlement trap w/cutoff</u>				<u>44.75</u>
	<u>B46A regulator</u>				<u>79.95</u>
	<u>BRASS</u>				<u>29.95</u>

WORK PERFORMED:	REGULATION INFORMATION	APPLIANCES/EQUIP. SOLD	CODE	SALES AMOUNT
<u>Run line to</u>	MAKE: <u>REGO</u> MODEL: <u>597Fc</u>	PARTS/MAT. USED	<u>(MS)</u>	<u>44.94</u>
<u>water heater</u>	DATE CODE: <u>11A22</u> VENT: <u>Down</u>	TANK RENT	<u>(CR)</u>	<u>(200.00)</u>
			<u>CF</u>	<u>14.95</u>

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐

I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.

X

CUSTOMER SIGNATURE

LEAK AND PRESSURE TEST

HIGH:	1st Stage	2nd Stage	LOW
START LOCK-UP:	<u>15.2</u> PSI	PSI	START LOCK-UP: <u>13.1</u> W.C.
TANK OFF: PRESSURE	<u>6.0</u> PSI	PSI	TANK OFF: PRESSURE <u>9.0</u> W.C.
AFTER 10 MINUTES:	<u>6.0</u> PSI	PSI	AFTER 10 MINUTES: <u>9.0</u> W.C.
PRESSURE AS LEFT:	<u>15.0</u> PSI	PSI	PRESSURE AS LEFT: <u>11.0</u> W.C.

PIPING PRESSURE TEST

START 6.0 PSIG FINISH 6.0 PSIG

SALES TAX _____ %

LABOR

O1

INV. TOTAL

AMOUNT RECEIVED

80.00 1.20
43.92 4.80
36.00

200.00
59.98

1802.32

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

Tom + Janie + Greg
SERVICE REP. SIGNATURE

2-4-2025
DATE

CUSTOMER SIGNATURE

WHITE/FILE COPY; YELLOW/CUSTOMER COPY; PINK/POSTING COPY