



congerlpgas.com

INVOICE / WORK ORDER NO. 120826

146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306 S. Main St.
Sylvester, GA 31791
(229) 776-7336

604-B N. Broadfoot Blvd.
Vidalia, GA 30474
(912) 537-8722

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

2310-B Highway 84 W
Valdosta, GA 31602
(229) 469-4250

NAME W J Baker RT# _____ RT. SEQ. _____ ACCT# 03-18332 DATE 2-26-25 INT _____

MAILING ADDRESS P.O. BOX 97 Ellenton GA CO. _____ CITY _____

ADDRESS 299 Terry Baker Rd APT/LOT NO. _____

CITY Ellenton STATE GA ZIP CODE 31747

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____

NEW CUSTOMER INFORMATION	
S.S. NO.	DELV
HOME PH	RENT
WORK PH	CREDIT
LITE PILOT	PC
EMPLOYER	
DR.	USE LEASE

email: _____
cell # 229-769-3113
PAY BILL ONLINE @congerlpgas.com

DIRECTIONS: Install New WH at old Barracks

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
1	REPLICE Rinnac WH		PKUA-113445	(WH)	999.95
1	Assortment of 3/4 Pipe + Fitting				225.00
1	3/4 Section Trap				49.95

WORK PERFORMED: <u>Installed New Water</u>	REGULATION INFORMATION		APPLIANCES/ EQUIP. SOLD	999.95	
	MAKE: <u>Ringo</u>	MODEL: <u>LD4403TR9</u>	PARTS/MAT. USED	MP 274.95	
	DATE CODE: <u>8-16</u>	VENT: <u>UC</u>	TANK RENT	MS 30.98	
SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE			CF	14.95	
SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:			SALES TAX	80.00 1.20	
LEAK AND PRESSURE TEST				22.00	
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐ 2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐ I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	HIGH:	1st Stage	2nd Stage	LOW	
	START LOCK-UP:	9.2 PSI	PSI	START LOCK-UP: 12.6 PSI	W.C.
	TANK OFF PRESSURE	6.6 PSI	PSI	TANK OFF PRESSURE 8.9 PSI	W.C.
	AFTER 10 MINUTES	6.6 PSI	PSI	AFTER 10 MINUTES 8.9 PSI	W.C.
	PRESSURE AS LEFT:	9.0 PSI	PSI	PRESSURE AS LEFT: 11.0 PSI	W.C.
	PIPING PRESSURE TEST			LABOR	240.00
START 6.0 PSIG FINISH 6.0 PSIG			GR	(200.00)	
CUSTOMER SIGNATURE _____			INV. TOTAL	1466.42	
			AMOUNT RECEIVED		

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

SERVICE REP SIGNATURE [Signature] DATE 2-26-25 CUSTOMER SIGNATURE _____