



congerlpgas.com

INVOICE / WORK ORDER NO.

120825

146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306 S. Main St.
Sylvester, GA 31791
(229) 776-7336

604-B N. Broadfoot Blvd.
Vidalia, GA 30474
(912) 537-8722

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

2310-B Highway 84 W
Valdosta, GA 31602
(229) 469-4250

NAME J+J Baker Farms RT# _____ RT. SEQ. _____ ACCT # 03-18332 DATE 2-26-25 INT _____

MAILING ADDRESS P.O. BOX 97 CO. _____ CITY _____

ADDRESS 299 Terry Baker Rd APT/LOT NO. _____

CITY Ellenton STATE GA ZIP CODE 31747

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____

NEW CUSTOMER INFORMATION

S.S. NO. _____ DELV _____
HOME PH _____ RENT _____
WORK PH _____ CREDIT _____
LITE PILOT _____ PC _____
EMPLOYER _____
DR. _____ USE _____ LEASE _____

email: _____

cell # 229-769-3113

PAY BILL ONLINE @congerlpgas.com

DIRECTIONS: Change Out 2 WH New Barnacks

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
2	REG 75E		PCCA-045050	WH	999.95
			PCCA-046127	WH	999.95

WORK PERFORMED: <u>Change Out</u>	REGULATION INFORMATION		APPLIANCES/ EQUIP. SOLD	CODE	1990	90
<u>Water Heater</u>	MAKE: <u>Rego</u>	MODEL: <u>LD443TR9</u>	PARTS/MAT. USED			
	DATE CODE: <u>7-08</u>	VENT: <u>UC</u>	TANK RENT			
SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE					CF	14.95
SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:			LEAK AND PRESSURE TEST		SALES TAX	160.00
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐	HIGH:	1st Stage	2nd Stage	LOW	_____ %	120
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A PAMPHLET NUMBER 54 ☐	START LOCK-UP:	9.1 PSI	PSI	START LOCK-UP:	12.1 W.C.	LABOR
	TANK OFF PRESSURE	6.0 PSI	PSI	TANK OFF PRESSURE	8.5 W.C.	(GR) (400.00)
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	AFTER 10 MINUTES:	6.0 PSI	PSI	AFTER 10 MINUTES:	8.5 W.C.	
	PRESSURE AS LEFT:	9.0 PSI	PSI	PRESSURE AS LEFT:	11.0 W.C.	
X _____	CUSTOMER SIGNATURE		PIPING PRESSURE TEST		INV. TOTAL	1956.05
	START	6.0 PSIG	FINISH	6.0 PSIG	AMOUNT RECEIVED	

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

[Signature]
SERVICE REP. SIGNATURE

2-26-25
DATE

X

CUSTOMER SIGNATURE