



congerlpgas.com

INVOICE / WORK ORDER NO.

120693

146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574306 S. Main St.
Sylvester, GA 31791
(229) 776-7336604-B N. Broadfoot Blvd.
Vidalia, GA 30474
(912) 537-87223117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-69422310-B Highway 84 W
Valdosta, GA 31602
(229) 469-4250NAME Cody Rogers RT# _____ RT. SEQ. _____ ACCT # 2-17369 DATE 1-9-25 INT _____

MAILING ADDRESS _____ CO. _____ CITY _____

ADDRESS 599 Pepper St APT/LOT NO. _____CITY Poulan STATE GA ZIP CODE 31781SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____WANTS EST ON K/H, RUN LINES and
set larger tank

DIRECTIONS:

Friday Afternoon 1-17-25

NEW CUSTOMER INFORMATION

S.S. NO. _____ DELV _____
HOME PH _____ RENT _____
WORK PH _____ CREDIT _____
LITE PILOT _____ PC _____
EMPLOYER _____
DR. _____ USE _____ LEASE _____

email:

cell # 881-7019

PAY BILL ONLINE @congerlpgas.com

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
TP	60	V084762	40%	Credit	MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL
TS	120	1528422	20	gallons Bld	369a1@3.7489			134.96	10.80
					209a1@3.849			76.98	4.16

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
	Rinnai	RE180e	SKUA-145314	(WH)	1199.95
	Sediment trap with auto valve				44.95
	B46R regulator				29.95
31'	1/2" copper			4.95	153.45
12'	3/8" copper			3.95	47.40
2	3/8 x 1/2 nip			3.95	7.90
	1/2 x 3/4 nip				3.95
	Plumbing				29.95
				(MP)	367.55
				(MS)	37.05

WORK PERFORMED	REGULATION INFORMATION	APPLIANCES/EQUIP. SOLD
Installed tankless water heater	MAKE: Rego MODEL: TR9	PARTS/MAT. USED
	DATE CODE: 08D2024 VENT: uc	TANK RENT

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐

I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.

X

CUSTOMER SIGNATURE

LEAK AND PRESSURE TEST

HIGH:	1st Stage	2nd Stage	LOW
START LOCK-UP:	9.2 PSI	PSI	START LOCK-UP: 13.1 W.C.
TANK OFF: PRESSURE	6.0 PSI	PSI	TANK OFF: PRESSURE 9.0 W.C.
AFTER 10 MINUTES:	6.0 PSI	PSI	AFTER 10 MINUTES: 9.0 W.C.
PRESSURE AS LEFT:	9.0 PSI	PSI	PRESSURE AS LEFT: 11.0 W.C.

PIPING PRESSURE TEST

START	4.0 PSIG	FINISH	4.0 PSIG
-------	----------	--------	----------

SALES TAX _____ %

LABOR

GR

01

01

INV. TOTAL

AMOUNT RECEIVED

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

SERVICE REP SIGNATURE

DATE

CUSTOMER SIGNATURE

WHITE/FILE COPY; YELLOW/CUSTOMER COPY; PINK/POSTING COPY