

1/24/2025 3:40:02 PM

WORK ORDER

Chad Muilenburg - Warehouse

1041 Humphrey Mill Rd
Mineral Bluff, GA 30559
(770) 364-4344

Customer #: 203301
Order #: 318723
Location #: 278815
Zone: B-014-WED-
Terms:

Tech: _____

Map Code:

Service Code: Propane Service

Description: 01/24/25 - FINAL HOOK - CALL 770-402-7255 - CT

Date Ordered: 1/24/2025	Scheduled Date:	Est. Completion:	Start:	Stop:
-------------------------	-----------------	------------------	--------	-------

Name:

Contract:

Manufact:

Notes:

Instructions:

Last Service:

SC Renewal:

Model:

Last Tune Up:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 203301Name: Chad Mulkenburg - WarehouseAddress: 1041 Humphrey Mill Rd.
Mineral Bluff GA 30559

Date: _____

Instructions: Final Hook up all
appliancesOrder #: 314723

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	<u>furnace</u>		<u>space heater</u>				
Manufacturer	<u>LENNOX</u>		<u>M.R. HEATER</u>				
Model #	<u>CX34-438-6F1</u>		<u>MHVBF30LPBT</u>				
Serial #	<u>6015409233</u>		<u>EC-9983052407730836</u>				
Burner/Combustion Chamber	<input checked="" type="checkbox"/> Ok	<input type="checkbox"/> N/A	<input checked="" type="checkbox"/> Ok	<input type="checkbox"/> N/A	<input type="checkbox"/> Ok	<input type="checkbox"/> N/A	<input type="checkbox"/> Ok
Manual Shutoff	<input checked="" type="checkbox"/> Ok	<input type="checkbox"/> N/A	<input checked="" type="checkbox"/> Ok	<input type="checkbox"/> N/A	<input type="checkbox"/> Ok	<input type="checkbox"/> N/A	<input type="checkbox"/> Ok
Sediment Trap	<input checked="" type="checkbox"/> Ok		<input checked="" type="checkbox"/> Ok		<input type="checkbox"/> Ok		<input type="checkbox"/> Ok
Pilot Safety System	<input checked="" type="checkbox"/> Ok	<input type="checkbox"/> N/A	<input checked="" type="checkbox"/> Ok	<input type="checkbox"/> N/A	<input type="checkbox"/> Ok	<input type="checkbox"/> N/A	<input type="checkbox"/> Ok
Electronic Ignition System	<input checked="" type="checkbox"/> Ok	<input type="checkbox"/> N/A	<input checked="" type="checkbox"/> Ok	<input type="checkbox"/> N/A	<input type="checkbox"/> Ok	<input type="checkbox"/> N/A	<input type="checkbox"/> Ok
Venting System	<input checked="" type="checkbox"/> Ok	<input type="checkbox"/> N/A	<input checked="" type="checkbox"/> Ok	<input type="checkbox"/> N/A	<input type="checkbox"/> Ok	<input type="checkbox"/> N/A	<input type="checkbox"/> Ok
Combustion Air	<input checked="" type="checkbox"/> Ok		<input checked="" type="checkbox"/> Ok		<input type="checkbox"/> Ok		<input type="checkbox"/> Ok
Taken Out of Service	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> Yes

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
<u>250</u>	<u>M2429720</u>	<u>good</u>	<u>trinc</u>	<u>2024</u>	<u>Ag</u>	<u>good</u>

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin	<u>Bego</u>	<u>404834</u>	<input checked="" type="checkbox"/> Correct <input type="checkbox"/> Incorrect	<u>11.1</u>	<u>12.8</u>
1st			<input type="checkbox"/> Correct <input type="checkbox"/> Incorrect		
2nd			<input type="checkbox"/> Correct <input type="checkbox"/> Incorrect		

Piping System Leak Test:**Pressure Test:**

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
<u>40</u> PSI	<u>40</u> PSI	<u>10</u> Mins	<input checked="" type="checkbox"/> Yes	_____ PSI	_____ PSI	_____ Mins	<input type="checkbox"/> Yes
_____ WC	_____ WC	_____ Mins	<input type="checkbox"/> No				<input type="checkbox"/> No

Comments: _____

Customer Acknowledgment: I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	<u>Alex Cash</u>	Service Technician (Signature)	<u>[Signature]</u>	Date	<u>1-24-25</u>
Customer (Print)	<u>CNAP</u>	Customer (Signature)		Date	



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 203301

Date: 1/23/25

Name CHAD MULLENBURG-WAREHOUSE

Instructions SET 250AG W/20G @2.999 RUN LINES, D
NOT LEAVE REG. CALL CHRIS TO ADVISE PLACEMENT

Address 1041 HUMPHREY MILL RD
MINERAL BLUFF, GA 30559

Order #: 317521

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check Yes No

Gas check attached Yes No

Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

#

EXP. DATE

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed.
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to year contract for discount.

CUSTOMER SIGNATURE

Retail Price

Contract Price

Rinnai \$	\$
Standard Vent Kit \$	\$
Standard Install \$	\$
Total \$	\$

Tank Set

New Cust Special

L.P. Gas /Gal 3.299	L.P. Gas /Gal 2.999	
Gallons 20	Gallons 20	
FRCC \$9.79	FRCC \$9.79	9.79
Fuel Total 65.98	Fuel Total 59.98	59.98
Tank Lease/YR 99.00	1st yr Lease FREE	FREE
Total Materials		
Sub-Total		
Sales Tax		
Tank Set Fee \$250	Tank Set Fee 20.00	20.00
Safety Inspection \$129.95	\$29.95	29.95
Total Labor		
Total charges		
Prepay Bal On Account		

Safe Appliance Savings	442.35
Safe Appliance Rebate	300.00

TOTAL BALANCE DUE