

Confirmed

2/17/2025 12:08:30 PM

WORK ORDER

Marc Nicholson - POH Scholarship Home

453 Settlers Road
Ellijay, GA 30540
(706) 455-1078

Customer #: 202473
Order #: 330091
Location #: 277798
Zone:
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 2/18/25 Run lines and drops; connect furnace. call
706-455-1078 INVOICE VM

Date Ordered: 2/17/2025	Scheduled Date:	Est. Completion:	Start:	Stop:
-------------------------	-----------------	------------------	--------	-------

Name:

Last Service: 11/25/2024

Last Tune Up:

Contract:

SC Renewal:

Manufact:

Model:

Notes:

Instructions:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 202473

Date: 2/18/25

Name: MARC NICHOLSON POH SCHOLARSHIP HOME

Instructions: RUN LINES & CONNECT FURNACE.

Address: 253 SETTLERS RIDGE

CALL 706-455-1078 INVOICEE VM

ELLIJAY GA 30540

Order #: 330091

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Furnace					
Manufacturer	Rheem					
Model #	R921V1005A21M45CAP					
Serial #	W122303156					
Burner/Combustion Chamber	<input checked="" type="checkbox"/> Ok	<input type="checkbox"/> Ok	<input type="checkbox"/> Ok	<input type="checkbox"/> Ok	<input type="checkbox"/> Ok	<input type="checkbox"/> Ok
Manual Shutoff	<input checked="" type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A
Sediment Trap	<input checked="" type="checkbox"/> Ok	<input type="checkbox"/> Ok	<input type="checkbox"/> Ok	<input type="checkbox"/> Ok	<input type="checkbox"/> Ok	<input type="checkbox"/> Ok
Pilot Safety System	<input checked="" type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A
Electronic Ignition System	<input checked="" type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A
Venting System	<input checked="" type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A
Combustion Air	<input checked="" type="checkbox"/> Ok	<input type="checkbox"/> Ok	<input type="checkbox"/> Ok	<input type="checkbox"/> Ok	<input type="checkbox"/> Ok	<input type="checkbox"/> Ok
Taken Out of Service	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
1000	252001526	Good	American	1995	UG	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			<input type="checkbox"/> Correct <input type="checkbox"/> Incorrect		
1st	R990	3403TR	4/24	<input checked="" type="checkbox"/> Correct <input type="checkbox"/> Incorrect	
2nd	R990	4403Y4	7/24	<input checked="" type="checkbox"/> Correct <input type="checkbox"/> Incorrect	11.4

Piping System Leak Test:**Pressure Test:**

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
50 PSI	50 PSI	10 Mins	<input checked="" type="checkbox"/> Yes	15 PSI	15 PSI	10 Mins	<input checked="" type="checkbox"/> Yes
WC	WC	Mins	<input type="checkbox"/> No				<input type="checkbox"/> No

Comments:

Customer Acknowledgment: I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	Service Technician (Signature)	Date
CNP	James Polman	2-18-25
Customer (Print)	Customer (Signature)	Date



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 202473
Name Marc Nicholson - Scholarship Home
Address 453 Settlers Road
Ellijay, GA 30540

Date: 09/25/2024
Instructions: Drop 1000UG w/50gal @2.999g; Drop
2 Anode Bags; Rough in with 8 drops
(hot water heater, 3 fireplaces, 2 lanterns,
hvac, and stove); (706) 455-1078; CHG, per RF;
Order #: 263646 CT

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check Yes No
Gas check attached Yes No
Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

#

EXP. DATE

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed.
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to year contract for discount.

CUSTOMER SIGNATURE

Retail Price		Contract Price
Rinnai	\$	\$
Standard Vent Kit	\$	\$
Standard Install	\$	\$
Total	\$	\$
Tank Set		New Cust Special
L.P. Gas /Gal	3.299	L.P. Gas /Gal 2.999
Gallons	50	Gallons 50
FRCC	\$9.79	FRCC \$9.79
Fuel Total	164.95	Fuel Total 149.95
Tank Lease/YR	179.00	1st yr Lease FREE
Total Materials		
Sub-Total		
Sales Tax		
Tank Set Fee	\$250	Tank Set Fee 20.00
Safety Inspection	\$129.95	\$29.95
Total Labor		
Total charges		
Prepay Bal On Account		
Safe Appliance Savings		537.58
Safe Appliance Rebate		300.00
TOTAL BALANCE DUE		



INVOICE

Customer #:	202473
Payment Terms:	Net 30
Invoice #:	330091
Invoice Date	2025-02-18
Total Due	\$688.93

Marc Nicholson - POH Scholarship Home

453 Settlers Road
Ellijay, GA 30540

Make Check Payable to: Folger Gas, LLC

Amount Enclosed: \$

Remit To:
Folger Gas, LLC
PO BOX 2155
Blue Ridge, GA 30513

Customer Name		Delivery/Service Address		Cust #	Invoice #	Inv Date
Marc Nicholson - POH Scholarship Home		453 Settlers Road - Ellijay, GA 30540		202473	330091	2025-02-18
Quantity	Item Number	Description	Unit Price	TOTAL		
22.00	12R50	1/2" COPPER TUBING	\$5.5000	\$121.00		
20.00	TR1	TRENCHING	\$1.5000	\$30.00		
2.00	45050	1/2" TEES	\$4.2500	\$8.50		
1.00	492012	1/2"FL X 1/2"FIP G	\$29.9500	\$29.95		
1.00	492011	3/8"FL X 1/2"FIP G	\$29.9500	\$29.95		
1.00	2464846	1/2X1/2 FIP CUTOFF	\$29.9500	\$29.95		
1.00	351979	1/2" PLUGS	\$4.2500	\$4.25		
2.00	3708	1/2" FLARE NUTS	\$3.7500	\$7.50		
1.00	37-6	3/8" CAP	\$3.5000	\$3.50		
1.00	501092	24" X 1/4 ID CONNE	\$24.9500	\$24.95		
1.00	45029	3/4" X 1/2" BLACK IRON ELBOW	\$3.0000	\$3.00		
6.00	45200	1/2" X CLOSE NIPPL	\$3.5000	\$21.00		
1.00	45126	1/2" UNIONS	\$24.9500	\$24.95		
2.00	45010	1/2" 90° ELBOWS	\$4.2500	\$8.50		
1.00	45225	1/2" X 12" BLK NIP	\$7.7500	\$7.75		
1.00	511414	1/2" M CONN	\$34.9500	\$34.95		
1.00	LV4403Y4	10PSI INLET 2PSI O	\$89.9500	\$89.95		
1.00	Shop Supplies	Shop Supplies	\$23.9800	\$23.98		
1.50	Labor	Labor	\$100.0000	\$150.00		
GA State Sales Tax:				\$20.16		
Gilmer County Tax:				\$15.14		

Tank/Equipment: Heating System -

For Fuel or Service At:

453 Settlers Road - Ellijay, GA 30540

Sub Total	\$653.63
Charges	\$0.00
Tax Total	\$35.30

ACCOUNT BALANCE	\$8,349.02	TOTAL DUE	\$888.93
-----------------	-------------------	-----------	-----------------

02/18/2025 - Technician: Mark Hooper - Work Performed: - Ran yard line hooked up 1st an 2nd stage reg. Hooked furnace and capped off log set line. Leak test at 50psi for 10mins. No leaks. Pressure test at 15psi for 10mins. No leaks. Mh jc

Folger Gas, LLC
PO BOX 2155
Blue Ridge, GA 30513
706-632-7606
www.folgergas.com