



146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306
Sylvester
(229)

Application ☒ Rinnai ☐ GPC
Gas Check ☒ Warranty ☒ Conger ☐
New Cust Pkg ☒ 5 Yr ☐ Inv ☐
Lease/Rent/Amt ☒ 4/4 Letter ☒

INVOICE / WORK ORDER NO.

113036

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

NAME Melena Bass RT# AH RT. SEQ. _____ ACCT # 1-23133 DATE 2/10/33 INT 1/2

MAILING ADDRESS _____ CO. _____ CITY _____

ADDRESS 441 Fillmore Rd APT/LOT NO. _____

CITY Fitzgerald STATE GA ZIP CODE 31750

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____

Set tank, Air lines, Convert Range,
Purchase & install Rinnai

DIRECTIONS: Get Customer to sign tank lease & Account Application

NEW CUSTOMER INFORMATION

S.S. NO. _____ DELV _____
HOME PH _____ RENT _____
WORK PH _____ CREDIT _____
LITE PILOT _____ PC _____
EMPLOYER _____
DR. _____ USE _____ LEASE _____
email: Melena.Chaney@McGm
cell # 229-721-3798
PAY BILL ONLINE @ congerlpgas.com

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
<u>TS</u>	<u>120</u>	<u>1525639</u>	<u>4</u>	<u>ON SITE</u>	MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
<u>20</u>	<u>3/8 LOPPED</u>				<u>79 00</u>
<u>1</u>	<u>Rinnai</u>	<u>RL752</u>	<u>PCC A045018</u>		<u>999 95</u>
	<u>Sediment</u>				<u>50 00</u>
	<u>Blue Regulator</u>				<u>79 95</u>
<u>2</u>	<u>Cutoff Valve</u>				<u>59 90</u>
<u>4</u>	<u>3/8 Flare nuts</u>				<u>11 80</u>
<u>3</u>	<u>MC</u>				<u>11 90</u>
	<u>Flex Connect</u>				<u>29 95</u>
	<u>Misc supplies</u>				<u>34 35</u>

WORK PERFORMED:	REGULATION INFORMATION	APPLIANCES/EQUIP. SOLD	CODE
<u>Set tank, Jerry</u>	MAKE: <u>Rego</u> MODEL: <u>TR9</u>		<u>WH</u>
<u>W/H + range</u>	DATE CODE: <u>802024</u> VENT: <u>DOWN</u>	PARTS/MAT. USED	<u>MP</u>
		TANK RENT	<u>TR</u>
			<u>CF</u>

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐

2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A PAMPHLET NUMBER 54 ☐

I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.

X _____ CUSTOMER SIGNATURE

LEAK AND PRESSURE TEST				SALES TAX	LABOR	W.C.	INVTOTAL
HIGH:	1st Stage	2nd Stage	LOW				
START LOCK-UP:	<u>11</u> PSI	PSI	START LOCK-UP:		<u>LB</u>		<u>250 00</u>
TANK OFF: PRESSURE	<u>9</u> PSI	PSI	TANK OFF: PRESSURE		<u>MS</u>		<u>34 35</u>
AFTER 10 MINUTES: PRESSURE	<u>4</u> PSI	PSI	AFTER 10 MINUTES: PRESSURE		<u>GC</u>	<u>OR</u>	<u>(400 00)</u>
AS LEFT:	PSI	PSI	AS LEFT:				

PIPING PRESSURE TEST

START PSIG FINISH PSIG

AMOUNT RECEIVED 1342.30

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

Eric Pahl SERVICE REP. SIGNATURE 2-18-25 DATE Melena Bass CUSTOMER SIGNATURE