CONGER FUELING LIFE LP GAS

146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306 S
Sylveste
(229)

Application ✓ Rinnai ____ GPC ____
Gas Check ✓ Warranty ✓ Conger ____
New Cust Pkg ____ 5 Yr ____ Inv ✓
Lease/Rent/Amt ___/___/29 Letter ✓

**INVOICE / WORK ORDER NO.**
112836

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

NAME Russ Griffin RT# AA RT. SEQ. ____ ACCT # 01-23078 DATE 2-5-25 INT EA

MAILING ADDRESS ____ CO. ____ CITY ____

ADDRESS 3524 Hwy 41 N. APT/LOT NO. ____

CITY Chula STATE GA ZIP CODE 31733

**NEW CUSTOMER INFORMATION**
S.S. NO. ____ DELV ____
HOME PH ____ RENT ____
WORK PH ____ CREDIT ____
LITE PILOT ____ PC ____
EMPLOYER ____
DR. ____ USE ____ LEASE ____

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED ____

email: griffinfarms81@gmail.com
cell # 229-392-6694
PAY BILL ONLINE @congerlpgas.com

RSC199ep, ~~Set 120~~, Run line (Rinnai only)

DIRECTIONS:

Rinnai: RSC199ep
RF.BA-083115

| TANK PICKUP/SET | TANK SIZE | SERIAL # ✓ | TANK % | TANK DESTINATION | DOT PERMANENTLY INSTALLED CONTAINERS | | | | |
|---|---|---|---|---|---|---|---|---|---|
| | | | | | MANUFACTURED DATE | LAST TEST DATE | SIZE | SERIAL # | % FULL |
| TS | 250 | 631806 | 9 | ONSITE | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |

| QTY | APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED | MODEL # | SERIAL NUMBER | UNIT PRICE | SALES AMOUNT |
|---|---|---|---|---|---|
| 30' | 3/8 COPPER | | | | 118 50 |
| 2 | 3/8 flare nuts | | | | 6 95 |
| | MIP | | | | 4 95 |
| | Cutoff valve | | | | 29 95 |
| | Bath Regulator | | | | 79 95 |
| | Sediment | | | | 50 00 |
| 1 | RSC199ep | RSC199ep | RFBA083115 | | 1299 95 |
| | misc supplies | | | | 28 22 |
| | | | | | |

WORK PERFOMED: Install w/ 1# + Run line

**REGULATION INFORMATION**
MAKE: Rego MODEL: TR9
DATE CODE: 802024 VENT: DOWN

| | CODE | |
|---|---|---|
| APPLIANCES/ EQUIP. SOLD | NH | 1,299 95 |
| PARTS/MAT. USED | MP | 290 30 |
| TANK RENT | TR | 20 00 |
| | CF | 14 95 |
| SALES TAX 8 % | 08 | 104.00 1.20 / 23.22 2.24 / 1.60 |
| LABOR | LB | 180 00 |
| | N-S | 28 22 |
| GPC | GR | (400 00) ⑧ |
| INV. TOTAL | | 1,565.70 |
| AMOUNT RECEIVED | | |

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐

2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A PAMPHLET NUMBER 54 ☐

I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.

X ____
CUSTOMER SIGNATURE

**LEAK AND PRESSURE TEST**

| HIGH: | 1st Stage | 2nd Stage | LOW |
|---|---|---|---|
| START LOCK-UP: | 11 PSI | PSI | START LOCK-UP: W.C. |
| TANK OFF: PRESSURE | 9 PSI | PSI | TANK OFF: PRESSURE W.C. |
| AFTER 10 MINUTES: | 9 PSI | PSI | AFTER 10 MINUTES: W.C. |
| PRESSURE AS LEFT: | 11 PSI | PSI | PRESSURE AS LEFT: W.C. |

**PIPING PRESSURE TEST**
START PSIG FINISH PSIG

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

Eric Pulliam
SERVICE REP. SIGNATURE

2-7-25
DATE

X ____
CUSTOMER SIGNATURE

WHITE/FILE COPY; YELLOW/CUSTOMER COPY; PINK/POSTING COPY; BLUE/OFFICE COPY