



INVOICE / WORK ORDER NO.

113324

MICHAEL BROOKS
229 392 5322
146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306
Sylves
(22)

Application ✓ Rinnai ✓ GPC ✓
Gas Check ✓ Warranty ✓ Inv ✓
New Cust Pkg ✓ 5 Yr ✓ Letter ✓
Lease/Rent/Amt ✓ ✓ ✓

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

NAME OMEGA PEANUT CO. RT# BX RT. SEQ. 1-23251 ACCT # 1-23251 DATE 2.20.25 INT AKA

MAILING ADDRESS Semi Dryer / Office @ location CO. GA CITY OMEGA

Physical ADDRESS 600 Colquhoun CO. LINE RD. APT/LOT NO.

CITY OMEGA STATE GA ZIP CODE 31775

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED

SET 120, RUN GAS LINE FOR 7.5 # PACKAGE UNIT
@ HOUSE BESIDE SEMI DRYERS

DIRECTIONS:

NEW CUSTOMER INFORMATION
S.S. NO. DELV
HOME PH RENT
WORK PH CREDIT
LITE PILOT PC
EMPLOYER
DR. USE LEASE
email: Omega Peanut Co @ gmail.com
cell # 229-528-4291
PAY BILL ONLINE @ congerlpgas.com

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
<u>TS</u>	<u>120</u>	<u>1528524</u>	<u>✓</u>	<u>ON SITE</u>	MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
<u>1</u>	<u>Rinnai</u>	<u>RUT5CP</u>	<u>PBCA-028346</u>		<u>999.95</u>
<u>1</u>	<u>646 R Reg</u>				<u>79.95</u>
<u>1</u>	<u>Sediment</u>				<u>50.00</u>
<u>1</u>	<u>Cutoff Valve</u>				<u>29.90</u>
<u>15</u>	<u>1/2 COLDS</u>				<u>89.25</u>
<u>2</u>	<u>1/2 flare nuts</u>				<u>5.95</u>
<u>2</u>	<u>MIP</u>				<u>8.92</u>
	<u>Misc supplies</u>				<u>26.64</u>

WORK PERFORMED:	REGULATION INFORMATION	APPLIANCES/ EQUIP. SOLD	CODE	
<u>Set tank, Rinnai</u>	MAKE: <u>Rego</u> MODEL: <u>TA9</u>	<u>W/H</u>	<u>999.95</u>	
<u>run line</u>	DATE CODE: <u>502024</u> VENT: <u>POWER</u>	PARTS/MAT. USED	<u>MIP</u>	<u>264.05</u>
		TANK RENT		

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:		LEAK AND PRESSURE TEST			SALES TAX		
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 <input type="checkbox"/>		HIGH:	1st Stage	2nd Stage	LOW	<u>8</u> %	<u>08</u> <u>80.00</u> <u>21.12</u> <u>1.20</u> <u>21.13</u>
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 <input type="checkbox"/>		START LOCK-UP:	<u>11</u> PSI	<u>11</u> PSI	START LOCK-UP:	W.C.	<u>LB</u> <u>180</u> <u>60</u>
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.		TANK OFF: PRESSURE	<u>7</u> PSI	<u>7</u> PSI	TANK OFF: PRESSURE	W.C.	<u>MS</u> <u>24</u> <u>44</u>
		AFTER 10 MINUTES: PRESSURE AS LEFT:	<u>7</u> PSI	<u>7</u> PSI	AFTER 10 MINUTES: PRESSURE AS LEFT:	W.C.	<u>GPC</u> <u>GR</u> <u>(400)</u> <u>00</u>
X CUSTOMER SIGNATURE		PIPING PRESSURE TEST			INV. TOTAL		<u>1130.04</u>
		START	PSIG	FINISH	PSIG	AMOUNT RECEIVED	

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

SERVICE REP. SIGNATURE

DATE

CUSTOMER SIGNATURE

WHITE/FILE COPY; YELLOW/CUSTOMER COPY; PINK/POSTING COPY; BLUE/OFFICE COPY