



INVOICE / WORK ORDER NO.

113325

Michael Brooks
229 392 5322146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574306
Sylvester
(229)Application ℓ Rinnai ℓ GPC
Gas Check ✓ Warranty ℓ Inv ℓ
New Cust Pkg 25 Yr Letter ✓
Lease/Rent/Amt ℓ ℓ ℓ ℓ3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942NAME OMEGA PEANUT CO. RT# BX RT. SEQ. ℓ ACCT # 1-07774 DATE 2.20.25 INT 498MAILING ADDRESS Semi dryers / Workshop CO. ℓ CITY ℓPhysical ADDRESS 600 Colquitt CO LINE RD APT/LOT NO. ℓCITY OMEGA STATE GA ZIP CODE 31775SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED ℓ

NEW CUSTOMER INFORMATION

S.S. NO. ℓ DELV ℓ
HOME PH ℓ RENT ℓ
WORK PH ℓ CREDIT ℓ
LITE PILOT ℓ PC ℓ
EMPLOYER ℓ
DR. ℓ USE ℓ LEASE ℓemail: Omega peanut co. gmail.com
cell # 229-528-4291

PAY BILL ONLINE @congerlpgas.com

DIRECTIONS:

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
	1000	J200473	✓	ON SITE	MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL
1	MID				MISC	Supplies		32	85
1	POL	315						5	95
								9	95

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
1	Rinnai	RL75CP	PCCA-045019		999.95
1	T29 Reg				79.95
1	B44 Reg				79.95
1	Sediment				50.00
1	Cutoff Valve				29.95
1	Flex Connection				29.95
	MUL BT				40.00
4	3/8 COPPER				15.80
2	3/8 Flex nut				5.95

WORK PERFORMED:	REGULATION INFORMATION	APPLIANCES/EQUIP. SOLD	CODE
Install w/ht	MAKE: <u>Rinnai</u> MODEL: <u>T29</u>	WH	999.95
Run line	DATE CODE: <u>52024</u> VENT: <u>DDW</u>	PARTS/MAT. USED	MP 347.45
		TANK RENT	

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:		LEAK AND PRESSURE TEST		SALES TAX
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.E.P.A. PAMPHLET NUMBER 58 ☐	HIGH:	1st Stage	2nd Stage	LOW
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.E.P.A. PAMPHLET NUMBER 54 ☐	START LOCK-UP:	4 PSI	PSI	START LOCK-UP:
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	TANK OFF:	7 PSI	PSI	TANK OFF:
	PRESSURE	7 PSI	PSI	PRESSURE
	AFTER 10 MINUTES:	7 PSI	PSI	AFTER 10 MINUTES:
	PRESSURE	7 PSI	PSI	PRESSURE
	AS LEFT:	7 PSI	PSI	AS LEFT:
X	PIPING PRESSURE TEST			INV. TOTAL
CUSTOMER SIGNATURE	START	PSIG	FINISH	PSIG
	AMOUNT RECEIVED			4,195.20

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

SERVICE REP. SIGNATURE Eric SubbhanDATE 2-27-25

CUSTOMER SIGNATURE