



146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

3
Sylv

Application Rinnai GPC
Gas Check Warranty Inv e
New Cust Pkg 5 Yr Letter ✓
Lease/Rent/Amt e e e

INVOICE / WORK ORDER NO.

113083

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

NAME Ray Peele (Kelly) EC RT# 0024 ACCT # 1-0700 DATE 2/24/25 INT 1/2

MAILING ADDRESS (Pd for by Gerald Peele) CO. GA CITY Lenox

ADDRESS 648 Parker Chapel Rd APT/LOT NO. 31637

CITY Lenox STATE GA ZIP CODE 31637

NEW CUSTOMER INFORMATION

S.S. NO. DELV
HOME PH RENT
WORK PH CREDIT
LITE PILOT PC
EMPLOYER DR. USE LEASE

email: kpeelefitness@gmail.com
cell # 229-686-3597

PAY BILL ONLINE @congerlpgas.com

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED

Run line, Purchase & install Rinnai

DIRECTIONS:

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
	500	1E046962	✓	VA SITE	MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
	<u>Rinnai</u>	<u>REP160e</u>	<u>PKUA113452</u>		<u>997.55</u>
10	<u>1/2 COPPER</u>				<u>49.50</u>
2	<u>Flare nuts</u>				<u>7.90</u>
2	<u>Cut off Valve</u>				<u>49.90</u>
1	<u>Back Regulator</u>				<u>79.95</u>
	<u>Sediment trap</u>				<u>40.00</u>
	<u>misc supplies</u>				<u>28.64</u>

WORK PERFORMED:	REGULATION INFORMATION	APPLIANCES/EQUIP. SOLD	CODE	
<u>Run line to C/H</u>	MAKE: <u>Rinnai</u> MODEL: <u>TR9</u>		<u>WH</u>	<u>999.95</u>
<u>+ Central Unit. Installed</u>	DATE CODE: <u>8/2024</u> VENT: <u>DOWN</u>	PARTS/MAT. USED	<u>MD</u>	<u>227.25</u>
<u>Rinnai</u>		TANK RENT	<u>MS</u>	<u>28.64</u>

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:		LEAK AND PRESSURE TEST		SALES TAX	
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐	HIGH: 1st Stage 2nd Stage LOW	START LOCK-UP: 11 PSI	START LOCK-UP: W.C.	LABOR	UB
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐	TANK OFF: PRESSURE 7 PSI	TANK OFF: PRESSURE W.C.	LABOR	GPC	Gr2
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	AFTER 10 MINUTES: 7 PSI	AFTER 10 MINUTES: W.C.			
	PRESSURE AS LEFT: 11 PSI	PRESSURE AS LEFT: W.C.			
X	PIPING PRESSURE TEST		INV. TOTAL		1,222.46
CUSTOMER SIGNATURE	START PSIG	FINISH PSIG	AMOUNT RECEIVED		

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

Eric P. Patten
SERVICE REP. SIGNATURE

2-25-25
DATE

X

CUSTOMER SIGNATURE