



146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306
Sylvester
(229)

Application Rinnai GPC
Gas Check ☒ Warranty ☒ Inv ☒
New Cust Pkg 5 Yr Letter ☒
Lease/Rent/Amt 41.10

INVOICE / WORK ORDER NO.

112807

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

NAME JOSEPH JOHNSON RT# AE RT. SEQ. _____ ACCT # 1-23153 DATE 3.19.25 INT PR

MAILING ADDRESS _____ CO. _____ CITY _____

ADDRESS 7203 DOSS DR. APT/LOT NO. _____

CITY TIFTON STATE GA ZIP CODE 31794

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____

NEW CUSTOMER INFORMATION

S.S. NO. _____ DELV _____

HOME PH _____ RENT _____

WORK PH _____ CREDIT _____

LITE PILOT _____ PC _____

EMPLOYER _____

DR. _____ USE _____ LEASE _____

email: glasha - Choice of hotmail.com

cell # 803-651-1901

PAY BILL ONLINE @congerlpgas.com

DIRECTIONS: _____

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
<u>TS</u>	<u>120</u>	<u>F4135</u>	<u>57</u>		MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL
					<u>68.4 GAL</u>				

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
<u>1</u>	<u>RINNAI RSG199cP PM.BA-304342</u>				<u>1299 95</u>
<u>1</u>	<u>PETERSON G102430-DNP-2072180 CHFR 30"</u>				<u>1529 96</u>
<u>5</u>	<u>1/2 COPPER + 2 FLARE NUTS</u>				<u>31 65</u>
<u>50</u>	<u>1/2 TRAC + 2 TRAC STRAIGHT FITTINGS</u>				<u>377 40</u>
<u>2</u>	<u>CUTOFF VALVES</u>				<u>49 90</u>
<u>1</u>	<u>SEDIMENT TRAP</u>				<u>30 00</u>
<u>1</u>	<u>B46R REGULATOR</u>				<u>79 95</u>
	<u>CENTRAL PLUMBING</u>				<u>1471 45</u>
	<u>PITTS ELECTRIC</u>				<u>300 00</u>

WORK PERFORMED:	REGULATION INFORMATION	APPLIANCES/EQUIP. SOLD	CODE
<u>SET 120, INSTALLED</u>	MAKE: <u>REGO</u> MODEL: <u>TR9</u>	<u>WH</u>	<u>AP</u>
<u>RINNAI & LOGS - RAN GAS LINE</u>	DATE CODE: <u>08D2024</u> VENT: <u>DOWN</u>	<u>mp/wh</u>	<u>568.90</u>
<u>NO LEAKS IN SYSTEM</u>		<u>TR/CF</u>	<u>10.00</u>

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE				SALES TAX	LABOR	INVTOTAL
SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:				<u>8%</u>	<u>08</u>	<u>122.40</u>
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐						<u>104.00</u>
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐						<u>45.51</u>
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.						<u>4.89</u>
X						<u>21.88</u>
CUSTOMER SIGNATURE						<u>00</u>
HIGH: 1st Stage 2nd Stage LOW						<u>450.00</u>
START LOCK-UP: 11 PSI PSI START LOCK-UP: 11.5 W.C.						<u>1471.45</u>
TANK OFF: PRESSURE 6 PSI PSI TANK OFF: PRESSURE 8 W.C.						<u>300.00</u>
AFTER 10 MINUTES: 6 PSI PSI AFTER 10 MINUTES: 8 W.C.						<u>273.53</u>
PRESSURE AS LEFT: 11 PSI PSI PRESSURE AS LEFT: 11.5 W.C.						<u>5,880.55</u>
PIPING PRESSURE TEST						
START PSIG FINISH PSIG						
AMOUNT RECEIVED						

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

SERVICE REP. SIGNATURE

3.19.2025
DATE

CUSTOMER SIGNATURE