



INVOICE

11133

HOME OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

NAME	<u>Bridgette Symanski</u>	ACCOUNT NO.	
MAIL ADDRESS	<u>6282 Fire Tower Rd.</u>	DATE ORDERED	
CITY/STATE/ZIP	<u>Surrency GA 31563</u>	DATE PROMISED	
PHONE	<u>732-642-9269</u>	DATE COMPLETED	<u>12-19-24</u>
LOCATION		TERMS	

INSTRUCTIONS set 250 gallon tank, run gas lines, install tankless water heater & generator

QTY.	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
1	250 gallon tank 2024 Quality Steel		2200 00
200	gallon of propane	2 99	598 00
1	Rinnai RL75e tankless water heater, serial #PDC A-067744		1285 00
1	24KW Generac generator G00721010 w/ auto changeover		6700 00
1	Generator Genpad		399 00
3	Rego regulator	69 95	209 85
82'	1/2" coated copper tubing	3 29	269 78
2	1/2" cut off valve	16 95	33 90
all	other gas fittings		79 59
all	water fittings & pipe, power wire, T-stud wire		76 73

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐

SERVICES PERFORMED

set 250 gallon tank,

TOTAL MATERIAL

11,851 85

installed tankless water heater & generator, converted generator to LP, ran gas lines, installed regulators & fittings, ran pressure check lit & checked water heater

TOTAL TIME

HOURS

LABOR

1100 00

THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.

SERVICES PERFORMED

BY

Daniel L. Egan, Jr., N.E. Noh.

SUBTOTAL

SALES TAX

948 15

TOTAL DUE

13,900 00

CUSTOMER'S SIGNATURE

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

INSTALLATION OR TURN ON	REMOVAL OR TURN OFF	LEAK AND PRESSURE TEST	
		HIGH	LOW
SIZE: <u>250</u>	SIZE	START LOCK UP:	START LOCK UP:
S/N: <u>1527688</u>	S/N:	TANK OFF PRESSURE:	TANK OFF PRESSURE:
GALLONS OR READING: <u>200</u>	GALLONS OR READING:	AFTER 10 MINUTES:	AFTER 10 MINUTES:
		PRESSURE AS LEFT:	PRESSURE AS LEFT:

-GPGA rebate 400.00
AMOUNT RECEIVED \$ 13,500

RECEIVED BY

DATE

SERVICES RECEIVED BY

WHITE/CUSTOMER'S COPY; YELLOW/POSTING COPY; PINK/FILE COPY

GASCheck - Gas Appliance System Check

Account Name _____ Invoice Number _____ Date 12/19/24
 Name Bridgette Symanski Company Sikes Propane, Inc.
 Address 6282 Fire Tower Rd. Call Taken By _____
 City Surrency State GA Zip 31563 Telephone (Cell) 732-642-9269 (Home) _____

Appliance Check

Appliance	<u>water heater</u>	<u>Generator</u>				
Manufacturer	<u>Rinnai</u>	<u>Generac</u>				
Model #	<u>RL750</u>	<u>G00721010</u>				
Serial #	<u>PD.CA-06</u> <u>7744</u>	<u>3015699865</u>				
BTU's	<u>180,000</u>	<u>355,000</u>				
Burner / Cont. Chamber	<u>ok</u>	<u>ok</u>				
Man. Shutoff / Sed. Trap	<u>installed</u>	<u>installed</u>				
Control / Pilot Safety System	<u>ok</u>	<u>ok</u>				
Venting System	<u>ok</u>	<u>ok</u>				
	<u>new</u>	<u>new</u>				
Taken Out Of Service Or Operation						

Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
<u>250</u>	<u>1527688</u>	<u>Quality Steel</u>	<u>2024</u>	<u>ok</u>	<u>new</u>	<u>09D22</u>	<u>ok</u>

Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held
<u>125psi.</u>	<u>125psi.</u>	<u>10min.</u>	<u>OK</u>
			<u>Work Order</u>

Piping Check

Materials	Size	Cover / Protection
<u>coated copper</u>	<u>1/2"</u>	<u>ok</u>

System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held
<u>9in.wc.</u>	<u>9in.wc.</u>	<u>10min.</u>	<u>OK</u>
			<u>Work Order</u>

Regulator Check

Type	Manufacturer	Date / Model	Vent Position / Protection
<u>first</u>	<u>Rego</u>	<u>06D2024 / LV4403TR9</u>	<u>u-c</u>
<u>second</u>	<u>Rego</u>	<u>04C2024 / LV4403B66R</u>	<u>down</u>
<u>second</u>	<u>Rego</u>	<u>10D2023 / LV3403B4</u>	<u>down</u>

Safety Information Supplied:

Comments: Please note all repairs and corrections made along with any recommended actions