

## INVOICE

FITZGERALD WATER LIGHT AND BOND  
P.O. Box 667  
FITZGERALD, GA 31750

(229) 426-5400

TO: JEFFERY SUMNER  
398 FRANK CHURCH RD  
OCILLA, GA 31774

INVOICE NO: 52855  
DATE: 2/21/25

CUSTOMER NO: 3591/3670

TYPE: RR - Residential Irwin Co

QUANTITY	DESCRIPTION	UNIT PRICE	EXTENDED PRICE
1.00	MDSE - Appliances SERIAL# SK.UA 145353 Inventory item selected for charge code: AP-60000163010 Quantity: 1.00 TANKLESS WTR HTR R75 LP	1,080.04	1,080.04
1.00	MDSE - Appliances Inventory item selected for charge code: AP-60000163011 Quantity: 1.00 PIPE COV ENCL 4 R75L	169.20	169.20
1.00	MDSE - Appliances Inventory item selected for charge code: AP-60000163032 Quantity: 1.00 PLUMBING INSTALLATION KIT	69.60	69.60
1.00	Sales Tax	105.51	105.51

TOTAL DUE: \$1,424.35

PLEASE DETACH AND SEND THIS COPY WITH REMITTANCE

DATE: 2/21/25 DUE DATE: 3/03/25  
CUSTOMER NO: 3591/3670

NAME: SUMNER, JEFFERY  
TYPE: RR - Residential Irwin Co

REMIT AND MAKE CHECK PAYABLE TO:  
FITZGERALD WATER LIGHT AND BOND  
P.O. Box 667  
FITZGERALD GA 31750

INVOICE NO: 52855  
TERMS: NET 10 DAYS

AMOUNT:

GA \$1,424.35  
Rebate 200.00  
1224.35



Account Number 3591  
 Name Jeffery Summer  
 Address 398 Frank Church Rd  
Ocala

Call Date: 2/7/25 Date Requested: 2/18/25  
 Instructions: set tank

Telephone Office: \_\_\_\_\_ Home: \_\_\_\_\_

Appliance Check Item:	Central Heating 1	Space Heater 2	Water Heater 3	Range 4	Clothes Dryer 5	6
Manufacturer			Rinnai			General
Model No.			RE180e			General
Serial No.			SK. UA-145353			60072189
Location			outside			outside
BTU	000	000	180 000	N/A	N/A	000 355 000
Age			new			new
Manual Shutoff (Installed/Existing)			Existing			Existing
Venting			gd			gd

TANK/CYLINDER 278 F

SIZE	SERIAL NUMBER	MFR.	MFR. DATE	Last Test Date	Location	Tank Cond.	Paint	Pigtail	Fittings	Gauge	Relief Valve			Fittings Leak Test
											Cond.	Date	Cap	
250	1530224	Quality Steel	2024	2/17/25	outside	new	new	new	new	new	new	new	new	Swirl

PIPING/REGULATOR OPERATION/CONDITION

PIPING/REGULATOR OPERATION/CONDITION

SINGLE STAGE		PIPING		REGULATOR DATE CODE	REGULATOR CONDITION	MFR.	MODEL	REG. VENT POSITION	HOW PROTECTED	FLOW PRESSURE
		MATERIAL	SIZE							
TWO STAGE	1ST	Copper	1/2	08/24	New	Rego	LV4403796	Level	Dome	11 IN. WC
	2ND	Copper	1/2	03/24	New	Rego	LV404B66	Level	overhang	10 PSIG
SYSTEM LEAK TEST										

SYSTEM LEAK TEST

SINGLE STAGE	Start Pressure	End Pressure	Time Held	System OK
	(Inches W.C.)	(Inches W.C.)		
	11	11	Swirl	OK
	(PSIG)	(PSIG)		
TWO STAGE	1ST			
	(Inches W.C.)	(Inches W.C.)		
	2ND			
	(Inches W.C.)	(Inches W.C.)		

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

This inspection covers (propane/LP-Gas) items and equipment visible and accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal working of sealed equipment, or structural components, and cannot be construed to cover future defects or unforeseen happenings.

Reference Invoice No. WF0522469 Date 2/18/25  
 (Mo. Day Yr.)

I, Jeffery Summer  
 (Please Print)

- Know how to turn off gas in case of emergency.
- Have smelled propane and can detect its odor.
- Have received the Consumer Safety Information.
- Had gas system deficiencies and / or corrections, if any, clearly explained to me.
- Am satisfied with the service work performed.

[Signature]  
 Customer's Signature

I, Chris Woods  
 (Please Print)

Certify that I have completed the System Check as prescribed

Performed Odor Test ☒ Yes

Performed Pressure Test ☒ Yes  
 Left Consumer Safety Info ☒ Yes

[Signature]  
 Delivery Man / Technician Signature