CONGER LP GAS — FUELING LIFE

congerlpgas.com

4-9-25

117545

146 S. Ridge Ave. Tifton, GA 31794 (229) 386-5574	306 S. Main St. Sylvester, GA 31791 (229) 776-7336	604-B N. Broadfoot Blvd. Vidalia, GA 30474 (912) 537-8722	3117 Veterans Parkway S. Moultrie, GA 31788 (229) 985-6942	2310-B Highway 84 W Valdosta, GA 31602 (229) 469-4250

03-23334

NAME Glenn Hunnicutt RT# ____ RT. SEQ. ____ ACCT # 03-23334 DATE 4-8-25 INT BP

MAILING ADDRESS 357 Sauls Rd CO. ____ CITY ____

ADDRESS ____ APT/LOT NO. ____

CITY Moultrie STATE GA ZIP CODE 31768

NEW CUSTOMER INFORMATION
S.S. NO. ____ DELV ____
HOME PH ____ RENT ____
WORK PH ____ CREDIT ____
LITE PILOT ____ PC ____
EMPLOYER ____
DR. ____ USE ____ LEASE ____

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED ____

email: Jobeth@Sccgroup.com
cell # 229-890-3882
PAY BILL ONLINE @congerlpgas.com

DIRECTIONS: @ Shop

Meds gas order
10 a month tank Rent

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL
TS	120	1528522							
		10 ×	3.99	= 39.99 +	4.40 +	14.95	=	59	34

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
10	gal gas				
1	Rinnai RU130IP		PCBA-652752		1399.95
1	Shutoff				19.95
1	Tape				6.00
1	Max-Trol				49.95
2	Flare nuts				4.18
2	Trac straights 3/4"				79.90
20	Trac				159.00
15	copper				74.25

WORK PERFOMED: TS Run line
Install TWH gas
Ck no leaks

REGULATION INFORMATION
MAKE: Rego MODEL: 49
DATE CODE: 2421 VENT: Hor

APPLIANCES/ EQUIP. SOLD	CODE	
	WH	1399.95
PARTS/MAT. USED	MP	447.23
~~TANK RENT~~	MS	48.43
	CF	14.95
SALES TAX ____ %	35.78 / 3.87	112.00 / 1.20 / .80
LABOR	LB	360.00
	TR	10.00
	GPC	(400.00)
INV. TOTAL		2093.55
AMOUNT RECEIVED	GPC	400.00
		2493.55

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐

2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A PAMPHLET NUMBER 54 ☐

I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.

X ____
CUSTOMER SIGNATURE

LEAK AND PRESSURE TEST

HIGH:	1st Stage	2nd Stage	LOW
START LOCK-UP	1.9 PSI	PSI	START LOCK-UP: W.C.
TANK OFF: PRESSURE	9" PSI	PSI	TANK OFF: PRESSURE W.C.
AFTER 10 MINUTES:	9" PSI	PSI	AFTER 10 MINUTES: W.C.
PRESSURE AS LEFT:	1.9 PSI	PSI	PRESSURE AS LEFT: W.C.

PIPING PRESSURE TEST
START PSIG FINISH PSIG

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

SERVICE REP. SIGNATURE ____ DATE 4-8-25 X ____ CUSTOMER SIGNATURE

WHITE/FILE COPY; YELLOW/CUSTOMER COPY; PINK/POSTING COPY