

GASCheck - Gas Appliance System Check

Account Name _____ Invoice Number _____ Date 3/18/25
 Name Burnham Berry Farms Company Sikes Propane, Inc.
 Address 930 Old Surrency Rd. Call Taken By _____
 City Barley State GA Zip 31513 Telephone (Cell) 912-218-7889 (Home) _____
 Appliance Check

Appliance	water heater	Cooktop	Cooktop	Cooktop	Cooktop	Cooktop	water heater
Manufacturer	Rinnai	Empava	Empava	Empava	Empava	Empava	Rinnai
Model #	RL75e	JTL H059 To CAZKA	← Same	← Same	← Same	← Same	RL75e
Serial #	NJ.4A-07 7633	5B70C202 1110649	5B70C202 1110656	5B70C202 1110650	5B70C202 1110648	5B70C202 1091278	
BTU's	180,000	37,600	37,600	37,600	37,600	37,600	180,000
Burner Conn. Chamber	ok	OK	OK	OK	OK	OK	ok
Man. Shutoff - Sed. Trap	existing	installed	installed	installed	installed	installed	existing
Control - Pilot Safety System	ok	OK	OK	OK	OK	OK	ok
Venting System	ok	OK	OK	OK	OK	OK	ok
Age	new	1yr	1yr	1yr	1yr	1yr	1yr
Taken Out Of Service Or Operation							

Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
350	78591	Delta	1973	OK	OK	3-12	OK

Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held	Y
110 psi.	110 psi.	10 min	Work Order	N

Piping Check

Materials	Size	Cover / Protection
Copper	1/2"	OK

System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held	Y
9 in. wc.	9 in. wc.	10 min	Work Order	N

Regulator Check

Type	Manufacturer	Date	Model	Vent Position / Protection
first	Bego	041899	LV4403TR9	u-c
second	Bego	12 BD9	LV4403B64	down

Safety Information Supplied: _____

Comments: Please note all repairs and corrections made along with any recommended actions