

SALES
SERVICE
INSTALLATION



ENERGY FOR EVERYONE
propane

RH/CH

1335 US Hwy 82 W, Leesburg, GA 31763 (229) 435-6116 FAX (229) 435-6119

Order Number 878835	Date Written 4/1/25	Taken By MEH	Schedule Date 4/3/25	Date Completed 4/3/25
Branch - Customer No. 1-04595	Home 229 343-6001	Work	Time Started 9:30 A.M.	Time Completed 3:00 P.M.
Name JESSE & MARY THOMPSON		Cell	DAWSON RD LFT HICKORY GRV LFT ON WINNSTEAD HO ON RT	
Address 188 WINNSTEAD DR City LEESBURG, GA		State GA	Zip 31763-5368	
Service Address 188 WINNSTEAD DR LEESBURG, GA 31763		** LOGS ONLY **		

Work to be performed: DELIVER AND INSTALL RINNAI RX180IN WITH INSTALL KIT, RXOVC OUTDOOR VENT CAP, PCD11-SHS PIPE COVER, XXXXXXXXXXXX . CALLED IN BY MARY ELIZABETH . 229-343-6001 CELL:	Work completed Ran gas line to Rinnai Up ✓ Copy
---	---

Qty:	Materials	Price	Amount	Qty:	Materials	Price	Amount
	RX180i			(1)	W-R RX180IN/P	✓	1290.00
	SJ.BA-149741				Rinnai Water Htr		
				(1)	W-R RIKF	✓	98.00
					Install		
				(1)	W-R RXOVC	✓	47.00
					Outdoor Vent Cap		
				(1)	W-R PCD11SHS	✓	143.00
					Pipe Cover		
				(1)	W-R MC-60-20	✓	119.00
					End of line		

DR. RT.		Rt. Seq.	Rate	Deposit	Tank Make		Size 120	Serial No. 903900	Tank Percent
Single Stage	Regular Date	Reg. Condition	Mfr.	Model	Vent Pos.	Protected?			
TWO	1st								
STAGE	2nd								

Less Check		Flow Check		Lock-up Check		SHOP OR TRUCK SUPPLIES		14 50	
Manometer Reading at Start	Manometer Reading After 10 minutes	Manometer Reading Under Load	Manometer Reading			MATERIAL TOTAL		1592 50	
9.6	9.6					TRIP CHARGE			
Central Heating		Water Heater		Range		LABOR			
Manufacturer		Rinnai		Clothes Dryer		SUB-LABOR		Rebate <200 00>	
Model No.		RX180IN/P				PERMIT			
Serial No.		SJ.BA-149741				SHIPPING/FREIGHT			
Sed. Trap		T T				Thank You		SALES TAX	
Vent		180		N/A				127 40	
Fuel/BTU		000		N/A				TOTAL	
AGE		New						1392 50	
Shut off Installed		y							

☐ CASH RECEIVED BY
☐ CHECK
 Work Completed by: Curtis Royce Date: 4/3/25
 Customer Signature: [Signature] Date: 4/3/25

I ACKNOWLEDGE THAT I HAVE READ AND UNDERSTAND THE IMPORTANT SAFETY INSTALLATION INFORMATION PRINTED ON BACK OF THE CUSTOMER COPY

ANY UNUSED GAS PIPING OUTLETS INDOORS? ☐ YES ☐ NO
 IF YES, IS EACH UNUSED GAS PIPING OUTLET FITTED WITH A GAS TIGHT THREADED PLUG OR CAP? ☐ YES ☐ NO
 CUSTOMER AVAILABLE ☐ YES ☐ NO
 CUSTOMER SMELLED ODORIZED PROPANE AND SHOWN THE SHUTDOWN PROCEDURE ☐ YES ☐ NO