



PROPANE GAS PIPING SYSTEM CHECK

Customer Account # 28255

Date 11/05/2024

Name: William S Tankersley

Instructions: Run lines and final hook up to house

Address: 737 Wildwood Trail

Shane (706) 633-8800; CCOF

Mineral Bluff, GA 30559

Order #: 277594

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	RANGE	RANGE	FURNACE	FURNACE
Manufacturer	FORNO	FORNO	TEMPSTAR	TEMPSTAR
Model #	NV	NV	EUPH25M7AE1	1715A1
Serial #	482200131	2310314	J22332877	422188060
Burner/Combustion Chamber	<input type="checkbox"/> Ok	<input type="checkbox"/> Ok	<input type="checkbox"/> Ok	<input type="checkbox"/> Ok
Manual Shutoff	<input type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A
Sediment Trap	<input type="checkbox"/> Ok	<input type="checkbox"/> Ok	<input type="checkbox"/> Ok	<input type="checkbox"/> Ok
Pilot Safety System	<input type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A
Electronic Ignition System	<input type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A
Venting System	<input type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A
Combustion Air	<input type="checkbox"/> Ok	<input type="checkbox"/> Ok	<input type="checkbox"/> Ok	<input type="checkbox"/> Ok
Taken Out of Service	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
500	m2432766	GOOD	IRIARC	2024	U/A	GOOD

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			<input type="checkbox"/> Correct <input type="checkbox"/> Incorrect		
1st	REGO	34041R	<input type="checkbox"/> Correct <input type="checkbox"/> Incorrect		
2nd	REGO	3404B4	<input type="checkbox"/> Correct <input type="checkbox"/> Incorrect	11.5	12.6

Piping System Leak Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
75 PSI	75 PSI	10 Mins	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	15 PSI	15 PSI	10 Mins	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
WC	WC	Mins					

Pressure Test:

Comments

Customer Acknowledgment: I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print) BRIAN BRADLEY	Service Technician (Signature) 	Date 5 NOV 24
Customer (Print) CWAFS	Customer (Signature) 	Date



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 28255

Name: WILLIAM TANKERSLEY

Address: 737 WILDWOOD TRAIL
MINERAL BLUFF, GA 30559

Date: 10/24/24

Instructions: T/I 500UG W/200G@2.999
CALL 706-633-8800 CCOF VM

Order #: 274589

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check Yes No
Gas check attached Yes No
Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

#

EXP. DATE

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed.
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to _____ year contract for discount.

CUSTOMER SIGNATURE

Retail Price

Contract Price

Rinnai \$	\$
Standard Vent Kit \$	\$
Standard Install \$	\$
Total \$	\$

Tank Set

New Cust Special

L.P. Gas /Gal 3.299	L.P. Gas /Gal 3.299
Gallons 50	Gallons 50
FRCC \$9.79	FRCC \$9.79
Fuel Total 164.95	Fuel Total 149.95
Tank Lease/YR 129.00	1st yr Lease FREE
Total Materials	
Sub-Total	
Sales Tax	
Tank Set Fee \$250	Tank Set Fee 20.00
Safety Inspection \$129.95	\$29.95
Total Labor	
Total charges	
Prepay Bal On Account	

Safe Appliance Savings 484.08
Safe Appliance Rebate 500.00

TOTAL BALANCE DUE