



INVOICE

No 11447

HOME OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

NAME	<u>Koby McLain</u>	ACCOUNT NO.	
MAIL ADDRESS	<u>1209 Midway Church Rd.</u>	DATE ORDERED	
CITY/STATE/ZIP	<u>Baxley GA 31513</u>	DATE PROMISED	
PHONE	<u>912-278-6765</u>	DATE COMPLETED	<u>8-20-26</u>
LOCATION		TERMS	

INSTRUCTIONS set 120 gallon tank, run all gas lines, install tankless water heater, fire box, gas logs, & range

QTY.	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
1	Rinnai RE160e tankless water heater w/ isolation valves, serial # WA.4A-001994		1250 00
1	Frigidaire FCRG3062AS gas range		799 00
1	Frigidaire GRPS LP conversion kit		29 95
1	Empire 32" Brackensidga fire box w/ T-stat blower		1357 95
1	Peterson G10-16/18-15(MP) 18" Charred frontier oak log		1269 50
100	gallon of propane	2.99	299 00
1	Gas ex box		39 99
125'	3/8" coated copper	3.29	411 25
All	other gas fittings, 24'-1/2" c. copper, cut off valves, supply		202 50

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐

THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME

X
CUSTOMER'S SIGNATURE

SERVICES PERFORMED

set 120 gallontank, ran all gas lines, installed tankless water heater, fire box, gas logs, & gas range, converted range to LP, ran pressure check, lit & checked appliances

TOTAL TIME _____ HOURS

TOTAL MATERIAL

5659 14

SUBTOTAL

SALES TAX 452 73

TOTAL DUE 7211 87

-GPGA rebate 250.00
AMOUNT
TOTAL \$ 6961.87

RECEIVED BY _____

DATE _____

SERVICES RECEIVED BY _____

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

INSTALLATION OR TURN ON	REMOVAL OR TURN OFF	LEAK AND PRESSURE TEST	
		HIGH	LOW
SIZE: <u>120</u>	SIZE	START LOCK UP:	START LOCK UP:
S/N: <u>25A054122</u>	S/N:	TANK OFF PRESSURE:	TANK OFF PRESSURE:
GALLONS OR READING: <u>100 gal</u>	GALLONS OR READING:	AFTER 10 MINUTES:	AFTER 10 MINUTES:
		PRESSURE AS LEFT:	PRESSURE AS LEFT:

WHITE/CUSTOMER'S COPY; YELLOW/POSTING COPY; PINK/FILE COPY

GASCheck - Gas Appliance System Check

Account Name _____ Invoice Number _____ Date 8/20/26
 Name Koby McLain Company Sikes Propane, Inc.
 Address 1209 Midway Church Rd. Call Taken By _____
 City Baxley State GA Zip 31513 Telephone (Cell) 912-278-6765 (Home) _____

Appliance Check

Appliance	Water Heater	Gas Logs	Range			
Manufacturer	<u>Rinnai</u>	<u>Peterson</u>	<u>Frigidaire</u>			
Model #	<u>RE160e</u>	<u>G10-16/18-15(CMP)</u>	<u>FCRG3062</u>			
Serial #	<u>WA-4A-001</u>	<u>2050011</u>	<u>VF551620</u>			
BTU's	<u>160,000</u>	<u>32,000</u>	<u>74,000</u>			
Burner / Com. Chamber	<u>ok</u>	<u>ok</u>	<u>ok</u>			
Man. Shutoff / Sed. Trap	<u>installed</u>	<u>installed</u>	<u>installed</u>			
Control / Pilot Safety System	<u>ok</u>	<u>ok</u>	<u>ok</u>			
Venting System	<u>ok</u>	<u>ok</u>	<u>ok</u>			
Age	<u>new</u>	<u>new</u>	<u>new</u>			
Taken Out Of Service Or Operation						

Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
<u>120</u>	<u>25A054122</u>	<u>American W.</u>	<u>2000</u>	<u>ok</u>	<u>ok</u>	<u>05-00</u>	<u>ok</u>

Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held
<u>150 psi.</u>	<u>150 psi.</u>	<u>10 min.</u>	<u>①</u> <u>N</u> Work Order <u>②</u> <u>N</u>

Piping Check

Materials	Size	Cover / Protection
<u>coated copper</u>	<u>1/2" + 3/8"</u>	<u>ok</u>

System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held
<u>9 in. wc.</u>	<u>9 in. wc.</u>	<u>10 min.</u>	<u>①</u> <u>N</u> Work Order <u>②</u> <u>N</u>

Regulator Check

Type	Manufacturer	Date / Model	Vent Position / Protection		
<u>Twin</u>	<u>Rego</u>	<u>08D2025/LV404B39</u>	<u>n-c</u>		

Safety Information Supplied:

Comments: Please note all repairs and corrections made along with any recommended actions.