



HOME OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

INVOICE

No 11450

NAME	<u>Jimmy Sellers</u>	ACCOUNT NO.	
MAIL ADDRESS	<u>1771 Jim Sellers Rd.</u>	DATE ORDERED	
CITY/STATE/ZIP	<u>Baxley GA 31513</u>	C. TE PROMISED	
PHONE	<u>912-245-8391</u>	DATE COMPLETED	<u>8-21-26</u>
LOCATION	<u>Andy</u>	TERMS	

INSTRUCTIONS install 250 gallon AG/UG tank, generator, & water heater

QTY.	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
1	250 gallon AG/UG Quality Steel propane tank		2500 00
1	9 Lb. anode bag		200 00
200	gallon of propane	2 99	598 00
1	24 KW Genac generator w/ auto changeover switch & battery		7200 00
1	Genpad		399 00
1	Rinnai RE180e tankless water heater w/ isolation valves		1400 00
	serial # WC.4A-028211		
3	Rego regulator	69 95	209 85
All	gas line, fittings, cut off valves, water pipe, thread sealant		495 90
1	Mini excavator rental		300 00

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER: 1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐ 2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐	SERVICES PERFORMED <u>installed 250 gallon AG/UG tank, tankless water heater, generator, genpad, gas lines, water line, ran pressure check, lit & checked out appliances</u>	TOTAL MATERIAL	13,302 75
	TOTAL TIME _____ HOURS	LABOR	1600 00
THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	SERVICES PERFORMED BY <u>Danif Sikes</u>	SUBTOTAL	
X _____ CUSTOMER'S SIGNATURE		SALES TAX	1064 22
		TOTAL DUE	15,966 97

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE				-GPGA rebate 200.00 AMOUNT \$ 15,766.97
		LEAK AND PRESSURE TEST		
INSTALLATION OR TURN ON	REMOVAL OR TURN OFF	HIGH	LOW	RECEIVED BY _____ DATE _____ SERVICES RECEIVED BY _____
SIZE: <u>250</u>	SIZE	START LOCK UP:	START LOCK UP:	
S/N: <u>1522104</u>	S/N:	TANK OFF PRESSURE:	TANK OFF PRESSURE:	
GALLONS OR READING: <u>200 gal</u>	GALLONS OR READING:	AFTER 10 MINUTES:	AFTER 10 MINUTES:	
		PRESSURE AS LEFT:	PRESSURE AS LEFT:	

WHITE/CUSTOMER'S COPY; YELLOW/POSTING COPY; PINK/FILE COPY

GASCheck - Gas Appliance System Check

Account Name _____ Invoice Number _____ Date 8/21/26
 Name Jimmy Sellers Company Sikes Propane, Inc.
 Address 1771 Jim Sellers Rd. Call Taken By _____
 City Baxley State GA Zip 31513 Telephone (Cell) 912-245-8391 (Home) _____

Appliance Check

Appliance	<u>Water heater</u>	<u>Generator</u>				
Manufacturer	<u>Rinnai</u>	<u>Generac</u>				
Model #	<u>RE180e</u>	<u>G00721010</u>				
Serial #	<u>WC. 4A-02 8211</u>	<u>30179827 65</u>				
BTU's	<u>180,000</u>	<u>355,000</u>				
Burner / Com. Chamber	<u>ok</u>	<u>ok</u>				
Man. Shutoff / Sed. Trap	<u>installed</u>	<u>installed</u>				
Control / Pilot Safety System	<u>ok</u>	<u>ok</u>				
Venting System	<u>ok</u>	<u>ok</u>				
Age	<u>new</u>	<u>new</u>				
Taken Out Of Service Or Operation						

Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
<u>250</u>	<u>1522104</u>	<u>Quality Steel</u>	<u>2024</u>	<u>ok</u>	<u>new</u>	<u>07E23</u>	<u>ok</u>

Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held
<u>155psi.</u>	<u>155psi.</u>	<u>10min</u>	<u>0</u>
			<u>0</u>

Piping Check

Materials	Size	Cover / Protection
<u>coated copper</u>	<u>1/2"</u>	<u>ok</u>

System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held
<u>9in.wc.</u>	<u>9in.wc.</u>	<u>10min.</u>	<u>0</u>
			<u>0</u>

Regulator Check

Type	Manufacturer	Date / Model	Vent Position/ Protection
<u>First</u>	<u>Rego</u>	<u>05C2025 / LV4403TR9</u>	<u>u-c</u>
<u>Second</u>	<u>Rego</u>	<u>06E2022 / LV4403B66R</u>	<u>down</u>
<u>Second</u>	<u>Rego</u>	<u>06C2022 / LV3403B4</u>	<u>down</u>

Safety Information Supplied:

Comments: Please note all repairs and corrections made along with any recommended actions.