



PARTNERS PROPANE OF GA,
INC.
PO BOX 277
BUTLER, GA 31006
(478) 862-4644

Cust ID CHAJOA
Account # 1471
Invoice # S0014726
Invoice Date 8/31/2026

Sold To
JOANNE CHASTAIN
470 GARDEN VALLEY RD
IDEAL, GA 31041-4308

Shipped To Location 1
JOANNE CHASTAIN
470 GARDEN VALLEY RD
IDEAL, GA 31041

Date 8/31/2026 Terms due upon receipt
Salesperson 7 Order Date
PO # Ship Via

Quantity	Category	Description	Unit Price	Amount
1.00	PROG40	Rheem 40 tall Water Heat	867.0000	\$867.00
		REGULAR SALES TAXABLE		69.36
1.00	39-8	1/2" SWIVEL NUT	5.0000	\$5.00
		REGULAR SALES TAXABLE		0.40
1.00	30-8	1/2"X1/2" FLARE CUTOFF	15.0000	\$15.00
		REGULAR SALES TAXABLE		1.20
1.00	48-8-8	1/2"X1/2" FI X Male Conn	2.8500	\$2.85
		REGULAR SALES TAXABLE		0.23
2.00	82855	MTG Clip 1/2 Tracpipe	0.2500	\$0.50
		REGULAR SALES TAXABLE		0.06
2.00	10034714	3/4 CPVC CTSxMPT Adapter	1.0000	\$2.00
	8			
		REGULAR SALES TAXABLE		0.16
1.00	20237005	3/4" CPVC Valve	10.0000	\$10.00
	6			
		REGULAR SALES TAXABLE		0.80
1.00		PERF REBATE	-200.0000	(\$200.00)

Subtotal	\$702.35
GA MACON CO TAX	\$72.21
HEADER	
Invoice Total	\$774.56

Total Due \$774.56

PROPANE SAFETY INSPECTION

Account # 1471 Name JOANNE CHASTAIN Address [1] 470 GARDEN VALLEY RD City IDEAL
 State GA Zip 31041 Phone 0 Date of Inspection 08/31/2026 Branch/Location Work Order #

Equipment Type	Water Heater				
Manufacturer	Rheem				
Year Manufactured					
Model #	Prog40-32p rh62				
Serial #	Q042631869				
Fuel	Propane				
BTUs (Maximum Input)	32,000				
Manual Shutoff Valve	OK				
Sediment Trap	NO				
Burner(s) Condition	OK				
Combustion Chamber Condition	OK				
Control/Pilot Safety System	OK Pilot				
Venting System	OK				
Combustion Air	Service Not Provided				
Taken Out of Svc or Operation (Tag #)	No				

CONTAINER CHECK	Serial #	Cust. Own	Container Type		Size	Tank %	Manufacturer	Mfr. Date	DOT		Container			Relief Valve			Fittings Leak Test
			ASME/ DOT	AG/UG/AGUG					Last Requal Date	Type	Found.	Loc.	Cond.	Cond.	Date	Cap	
	2sg066187		ASME	AG	250 wg		American Welding	2003	N/A		OK	OK	OK	OK	NV	OK	OK

PIPING		Material	Size	Protection	REGULATORS		Mfr.	Model #	Date Code	Cond.	Vent Position	Protection
	1st Stg	CT (Copper Tubing)	1/2	OK		1st Stg	Fisher	R622H-HGJ	2003	OK	OK	OK
	2nd Stg	CT (Copper Tubing)	1/2	OK		2nd Stg	REGO	2503	1990	OK	OK	OK

CSST TRACKING (IF APPLICABLE) Bonded ☐ Yes ☐ No ☐ Unknown Jurisdictional Acct. ☐ Y ☒ N ☐ Unknown Gas Lines Capped ☐ Y ☒ N/A Heat Pump ☐ Y ☒ N

System Type	System Leak Check ☒ Entire System					Pressure Test				System Operation Tests							
	Initial/Start Pressure		End Pressure	Start Time	End Time	Start Pressure		End Pressure	Start Time	End Time	Flow Pressure Test		Lock-Up Pressure Test				
1st Stage	13	8	☐ WC ☐ PSI	8	☐ WC ☐ PSI	11:45	11:50	10	PSI	10	PSI	11:35	11:45	11	☐ WC ☐ PSI	13	☐ WC ☐ PSI
			☐ WC ☐ PSI		☐ WC ☐ PSI				PSI		PSI				☐ WC ☐ PSI		☐ WC ☐ PSI
			☐ WC ☐ PSI		☐ WC ☐ PSI				PSI		PSI				☐ WC ☐ PSI		☐ WC ☐ PSI
			☐ WC ☐ PSI		☐ WC ☐ PSI				PSI		PSI				☐ WC ☐ PSI		☐ WC ☐ PSI

Performed Sniff Test ☒ Y ☐ N Comments Installed prog40 lit and checked.; ;

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

I, ☒ Property Owner ☐ Tenant ☐ Authorized Representative, acknowledge that the individual performing the propane safety review informed me of the procedure and the outcome of the review; what was covered by the review and what was not covered; what repairs and/or alterations, if any, were made to the gas system or appliances; and options available for making recommended changes to my gas system. I further acknowledge that:

- I have informed the individual performing the propane safety review of all gas-burning appliances and gas lines on my property.
- I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas off at the tank.
- I have smelled the propane gas and can detect its odor.
- I have been told that the odorant giving propane its distinctive smell can fade or diminish in intensity.

In addition, I have been told that certain physical limitations or conditions might prevent me from smelling a gas leak.

- I have received customer safety information and been told to read it and share it with all family members.
- I am satisfied with the service work performed.
- I have been advised to install one or more gas and carbon monoxide detectors listed by Underwriters Laboratories (UL) as an additional measure of safety.

I have been provided the following additional safety materials:

- ☒ Propane Safety Booklet (PRC-005606 or PRC-101063)
- ☒ Important Propane Safety Information Brochure (PRC-003121 or PRC-101062)
- ☒ Carbon Monoxide Brochure (PRC-000075)

Tyler Robinson

Service Technician Name - Print




Service Technician Signature

08/31/2026

Date

JOANNE CHASTAIN

Customer Name - Print



Customer Signature

08/31/2026

Date