

Confirmed G

8/11/2026 9:58:41 AM

WORK ORDER

Brandon Roland

2490 New Hope Road
Morganton, GA 30560
(770) 656-0403

Customer #: 206242
Order #: 534863
Location #: 282470
Zone: B-013-FRI-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 08/12/26 - C/C STOVE KIT ON SITE - CALL TIM 770-627-8644
- EMAIL INVOICE - CT

Date Ordered: 8/11/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
Name:	Last Service: 8/7/2026		Last Tune Up:	
Contract:	SC Renewal:			
Manufact:	Model:			
Notes:				
Instructions:				

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 206242

Name: BRANDON ROLAND

Address: 2490 NEW HOPE ROAD

MORGANTON, GA 30560

Date: 8/12/26

Instructions: C/C STOVE KIT ON SITE CALL TIM

770-627-8644 EMAIL INVOICE

Order #: 534863

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Stove					
Manufacturer	Frigidaire					
Model #	GCFG3060BAF					
Serial #	VFG2252324					
Burner/Combustion Chamber	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
250	m2504388	Good	Triarc	2025	NE	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	17150	3403T129	1-24	☒ Correct ☐ Incorrect	
2nd	17150	340334	4-25	☒ Correct ☐ Incorrect	11.6

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
100 PSI	100 PSI	10 Mins	☒ Yes				☐ Yes
			☐ No				☐ No

Comments:

Customer Acknowledgment:

 I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	Ash Wiley	Service Technician (Signature)	[Signature]	Date	8-12-26
Customer (Print)	Customer not present	Customer (Signature)	[Signature]	Date	



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 206242

Name **BRANDON ROLAND**

Address **2490 NEW HOPE ROAD**
MORGANTON GA 30560

Date: 6/19/26

Instructions: **DROP 250UG ANODE BAG AND 50FT OF
COPPER DROP TANK CLOSE TO DUMP TRAILER CCOF-CLT**

Order #515628

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check Yes No

Gas check attached Yes No

Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

#

EXP. DATE

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed.
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to _____ year contract for discount

CUSTOMER SIGNATURE

Retail Price

Contract Price

Rinnai \$	\$
Standard Vent Kit \$	\$
Standard Install \$	\$
Total \$	\$

Tank Set

New Cust Special

L P Gas /Gal 2.999	L P Gas /Gal 2.499	
Gallons 50	Gallons 50	
FRCC \$9.79	FRCC \$9.79	9.79
Fuel Total 149.95	Fuel Total 124.95	124.95
Tank Lease/YR 129.00	1st yr Lease FREE	FREE
Total Materials		
Sub-Total		
Sales Tax		
Tank Set Fee \$250	Tank Set Fee 20.00	20.00
Safety Inspection \$129.95	\$29.95	29.95
Total Labor		
Total charges		
Prepay Bal On Account		

Safe Appliance Savings 474.57

Safe Appliance Rebate 50.00

TOTAL BALANCE DUE