

500

8/18/2026 12:03:27 PM

WORK ORDER

David Massey

1990 Big Creek Road
Cherry Log, GA 30522
(386) 503-0408

Customer #: 206552
Order #: 536122
Location #: 282828
Zone: B-016-THU-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 8/20/26 T/I 325Ag w260G @2.499 JODY WILL SHOW YOU

WHERE TO SET THE TANK run yard line and light pilot lights
Call Jody 706-455-6408 Keys are on the exterior fireplace
mantel Email invoice to jodywilson5@gmail.com - cit

Date Ordered:	Scheduled Date:	Est. Completion:	Start:	Stop:
---------------	-----------------	------------------	--------	-------

Name:

Contract:

Manufact:

Notes:

Instructions:

Last Service:

SC Renewal:

Model:

Last Tune Up:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------

9



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 206552

Name: DAVID MASSEY

Address: 1990 BIG CREEK ROAD

CHERRY LOG, GA 30522

Date: 8/20/26

Instructions: T/I 325AGW/260G@2.499G RUN YD LINE AND
LIGHT PILOTS. CALL JODY 706-455-6408- EMAIL
INVOICE.

Order #: 536122

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	log set	log set	log lighter	water heater
Manufacturer	Empire	Empire	N.V.	Navien
Model #	VFSR 24-4	VFSR 24-4	N.V.	NPE-150S2
Serial #	1730928416	143934148	N.V.	202SW247043
Burner/Combustion Chamber	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A
Manual Shutoff	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A
Sediment Trap	☒ Ok	☒ Ok	☒ Ok	☒ Ok
Pilot Safety System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A
Combustion Air	☒ Ok	☒ Ok	☒ Ok	☒ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☒ No	☐ Yes ☒ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
325	797358	Good	American	1993	76	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	MEC	1222H	☒ Correct ☐ Incorrect		
2nd	Rego	4403133	☒ Correct ☐ Incorrect	11.8	13.6

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
115 PSI	115 PSI	0 Mins	☒ Yes	15 PSI	15 PSI	10 Mins	☒ Yes
WC	WC	Mins	☐ No				☐ No

Comments:

Customer Acknowledgment:

 I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	Service Technician (Signature)	Date <u>8-20-26</u>
Customer (Print)	Customer (Signature)	Date



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 206552
Name DAVID MASSEY
Address 1990 BIG CREEK ROAD
CHERRY LOG, GA 30522

Date: 8/20/26
Instructions: T/I 325AGW/260G@2.499G RUN YD LINE
LIGHT PILOTS CALL JODY 706-455-6408 EMAIL INVOIC
Order #: 536122

DESCRIPTION OF WORK
COMMENTS:
SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY	
Performed leak check	Yes ____ No ____
Gas check attached	Yes ____ No ____
Leak check	Initial ____
Start Pressure	End Pressure
Time Held	System OK

% in Tank

AMOUNT REC'D
\$
☐ CASH ☐ CHECK #
☐ CREDIT CARD
#
EXP. DATE
* I have received the Consumer Safety information & material.
* I am satisfied with the work performed.
* Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
* Signing agrees to _____ year contract for discount.
CUSTOMER SIGNATURE

Retail Price	Contract Price	
Rinnai \$	\$	
Standard Vent Kit \$	\$	
Standard Install \$	\$	
Total \$	\$	
Tank Set	New Cust Special	
L.P. Gas /Gal 2.999	L.P. Gas /Gal 2.499	
Gallons 260	Gallons 260	
FRCC \$9.79	FRCC \$9.79	9.79
Fuel Total 770.74	Fuel Total 649.74	649.74
Tank Lease/YR 99.00	1st yr Lease FREE	FREE
Total Materials		
Sub-Total		
Sales Tax		
Tank Set Fee \$250	Tank Set Fee 20.00	20.00
Safety Inspection \$129.95	\$29.95	29.95
Total Labor		
Total charges		
Prepay Bal On Account		
Safe Appliance Savings		575.03
Safe Appliance Rebate		200.00
TOTAL BALANCE DUE		