

WORK ORDER

FANNIN CO STN #11 (EMS)

12811 MORGANTON HWY
MORGANTON, GA 30560
(706) 455-3934

Customer #: 25227
Order #: 537037
Location #: 271808
Zone: B-012-FRI-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 8/25/26 C/C stove kit on site *in package* Call 706-455-3934 Code 5511 door
between 2 bay doors Email invoice - clt

Date Ordered: 8/24/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
Name: Heating System	Last Service: 8/20/2026	Last Tune Up:		
Contract:	SC Renewal:			
Manufact:	Model:			
Notes:				
Instructions:				

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 25227

Name: FANNIN CO STN #11 EMS

Address: 12811 MORGANTON HWY

MORGANTON GA 30560

Date: 8/25/26

Instructions: C/C STOVE KIT IN PACKAGE EMAIL

INVOICE CLT

Order #: 537037

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Stove Top					
Manufacturer	Frigidaire					
Model #	FCRB3062ASH					
Serial #	VF55162153					
Burner/Combustion Chamber	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
500	64009 LMC	Good	Bigwell	1962	AG	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	Rego LV3403TR	01/17	☒ Correct ☐ Incorrect		
2nd	Rego 4403	NA	☒ Correct ☐ Incorrect	11.3	13.1

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
95 PSI	95 PSI	10 Mins	☒ Yes ☐ No	____ PSI	____ PSI	____ Mins	☐ Yes ☐ No
____ WC	____ WC	____ Mins					

Comments:

Customer Acknowledgment: I acknowledge, by checking each of the following items, that:

- ☒ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☒ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☒ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☒ I have smelled propane gas and can detect its odor.
- ☒ I have been told to consider installing one or more gas detectors.
- ☒ I have received safety information and told to read it and share it with all family members.
- ☒ I am satisfied with the service work performed.

Service Technician (Print) Fernando Sordo	Service Technician (Signature) 	Date 8/25/26
Customer (Print) Robert Poole	Customer (Signature) 	Date

