

8/21/2026 11:19:01 AM

WORK ORDER

Norman Harris

142 Arbor Lane
Blairsville, GA 30512
(603) 491-4162

Customer #: 206449
Order #: 536755
Location #: 282716
Zone: B-018-MON-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 8/24/26 Test w/h - c/c stove Call Ben 910-964-4599 CCOF-CLT

kit on site

Date Ordered: 8/21/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
-------------------------	-----------------	------------------	--------	-------

Name:

Last Service: 8/19/2026

Last Tune Up:

Contract:

SC Renewal:

Manufact:

Model:

Notes:

Instructions:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 206449

Date: 8/24/26

Name: NORMAN HARRIS

Instructions TEST W/H-C/C STOVE KIT
ON SITE CCOF-SLM

Address: 142 ARBOR LANE

Order #: 536755

BLAIRSVILLE GA 30512

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Stove					
Manufacturer	G.E.					
Model #	PGS930YP9FS					
Serial #	DD484111P					
Burner/Combustion Chamber	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
500	M2601306	Good	Triarc	2026	U.G.	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	Rego	LV3403TR9 02-2026	☒ Correct ☐ Incorrect		
2nd	Rego	LV3403B4 05-2025	☒ Correct ☐ Incorrect	11.5	13.8

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
110 PSI	110 PSI	10 Mins	☒ Yes	15 PSI	15 PSI	10 Mins	☒ Yes
WC	WC	Mins	☐ No				☐ No

Comments:

Customer Acknowledgment:

 I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	Jeff D. Lind	Service Technician (Signature)	[Signature]	Date	8-24-26
Customer (Print)	C.N.A.	Customer (Signature)	[Signature]	Date	



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 206449

Name **NORMAN HARRIS**

Address **30 ARBOR LANE**

BLAIRSVILLE GA 30512

Date: 7/31/26

Instructions: **DROP 500 UG W/ 50G @2.499**
ANODE BAG GC TO BURY POSSIBLY RN LINE

Order #527738

CCOF
CLT

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check Yes No

Gas check attached Yes No

Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

#

EXP. DATE

* I have received the Consumer Safety information & material

* I am satisfied with the work performed

* Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.

* Signing agrees to year contract for discount

CUSTOMER SIGNATURE

Retail Price		Contract Price	
Rinnai	\$	\$	
Standard Vent Kit	\$	\$	
Standard Install	\$	\$	
Total	\$	\$	
Tank Set		New Cust Special	
L.P. Gas /Gal	2.999	L.P. Gas /Gal	2.499
Gallons	50 150	Gallons	50 150
FRCC	\$9.79	FRCC	\$9.79
Fuel Total	149.95	Fuel Total	124.95
Tank Lease/YR	129.00	1st yr Lease	FREE
Total Materials			
Sub Total			
Sales Tax			
Tank Set Fee	\$250	Tank Set Fee	20.00
Safety Inspection	\$129.95		\$29.95
Total Labor			
Total charges			
Prepay Bal On Account			
Safe Appliance Savings		494.78	532.65
Safe Appliance Rebate		50.00	
TOTAL BALANCE DUE			