



congerlpgas.com

INVOICE / WORK ORDER NO.

126174

146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574306 S. Main St.
Sylvester, GA 31791
(229) 776-7336604-B N. Broadfoot Blvd.
Vidalia, GA 30474
(912) 537-87223117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-69422310-B Highway 84 W
Valdosta, GA 31602
(229) 469-4250

AE Second Baptist

RT#

RT. SEQ.

ACCT #

25528

DATE

4-29-26

INT 2

MAILING ADDRESS

CO.

CITY

ADDRESS

408 Riley Road

APT/LOT NO.

CITY

Waycross

STATE

Ga

ZIP CODE

31503

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED

NEW CUSTOMER INFORMATION

S.S. NO.

DELV

HOME PH

RENT

WORK PH

CREDIT

LITE PILOT

PC

EMPLOYER

DR.

USE

LEASE

email: sbmistyperkins@gmail.com

cell # 912 283-0436

PAY BILL ONLINE @congerlpgas.com

DIRECTIONS:

Set vertical 120, mount WH,
Run lines

* BRING VENT CAP BACK

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
SET	120	2897562	0	ONSITE	MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
1	2x199IN	2x199	BA-176681		1750.00
1	SEDIMENT TRAP				50.00
	B46R				89.95
2	FLARE NUTS 1/2"				5.90
20	1/2" Copper 20				124.00
1	1/2"x1/2"min COTTON				24.99
	Register product on 9/29/24				
	Rebate 27169				

WORK PERFORMED:	SET 120, RUN LINE	REGULATION INFORMATION		APPLIANCES/EQUIP. SOLD	CODE			
TO WH.	MAKE: RECNO	MODEL: TR9	PARTS/MAT. USED	MP	2044.84			
	DATE CODE: 02B2025	VENT: DOWN	TANK RENT	TR	100.00			
SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE					MS	133.49		
SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:			LEAK AND PRESSURE TEST		SALES TAX	8.00		
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐	HIGH:		1st Stage	2nd Stage	LOW	163.59		
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐	START LOCK-UP:		11 PSI	PSI	W.C.	180.00		
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	TANK OFF:		8 PSI	PSI	W.C.			
	PRESSURE		8 PSI	PSI	W.C.			
	AFTER 10 MINUTES:		8 PSI	PSI	W.C.			
	PRESSURE AS LEFT:		11 PSI	PSI	W.C.			
CUSTOMER SIGNATURE			PIPING PRESSURE TEST		INV. TOTAL	2640.00		
			START	PSIG	FINISH	PSIG	AMOUNT RECEIVED	

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

SERVICE REP. SIGNATURE

DATE

CUSTOMER SIGNATURE

WHITE/FILE COPY; YELLOW/CUSTOMER COPY; PINK/POSTING COPY