



congerlpgas.com

122581 ✓

146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306 S. Main St.
Sylvester, GA 31791
(229) 776-7336

604-B N. Broadfoot Blvd.
Vidalia, GA 30474
(912) 537-8722

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

2310-B Highway 84 W
Valdosta, GA 31602
(229) 469-4250

NAME The Farm & Oke RT# _____ RT. SEQ. _____ ACCT # 8-25147 DATE 9/23/26 INT ED

MAILING ADDRESS CHICKEN PROCESSOR Center CO. _____ CITY _____

ADDRESS 103 Doc Rider Rd. APT/LOT NO. _____

CITY Folkston STATE GA ZIP CODE _____

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____

NEW CUSTOMER INFORMATION
S.S. NO. _____ DELV _____
HOME PH _____ RENT _____
WORK PH _____ CREDIT _____
LITE PILOT _____ PC _____
EMPLOYER _____
DR. _____ USE _____ LEASE _____

email: bradley@okfarm.com

cell # 904-403-4593

PAY BILL ONLINE @congerlpgas.com

DIRECTIONS: INSTALL W/H, SET TANK + RUN LINE
Added Monitor
10:15 - 11:15
MONITOR# 29648144

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL
<u>TS</u>	<u>120</u>	<u>1559452</u>	<u>9</u>	<u>ON SITE</u>					

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
<u>1</u>	<u>Rinna</u>	<u>RE180</u>	<u>TJUA-128432</u>		<u>1199 95</u>
<u>1</u>	<u>Back Regulator</u>				<u>89 95</u>
<u>1</u>	<u>Sediment Trap</u>				<u>50 00</u>
<u>1</u>	<u>Cutoff Valve</u>				<u>29 95</u>
<u>2</u>	<u>3/8 FLARE NUTS</u>				<u>6 95</u>
<u>15</u>	<u>3/8 COPPER</u>				<u>89 25</u>
	<u>Rebate ID # 27184 Approved</u>				
	<u>also Dic GPC</u>				

WORK PERFORMED: <u>SET TANK, INSTALL</u>	REGULATION INFORMATION	APPLIANCES/EQUIP. SOLD	CODE	
<u>PLUMBING + RUN LINE</u>	MAKE: <u>REGO</u>	PARTS/MAT. USED	<u>WH</u>	<u>1199 95</u>
	DATE CODE: <u>702025</u>	TANK RENT	<u>MP</u>	<u>264 10</u>
	VENT: <u>DOWN</u>		<u>MS</u>	<u>26 76</u>
SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE				<u>18 95</u>
SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:		LEAK AND PRESSURE TEST		SALES TAX _____ %
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐	HIGH: 1st Stage	2nd Stage	LOW	
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐	START LOCK-UP: <u>11.5</u> PSI	PSI	START LOCK-UP: _____ W.C.	<u>180 00</u>
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	TANK OFF: <u>5.5</u> PSI	PSI	TANK OFF: PRESSURE _____ W.C.	
	AFTER 10 MINUTES: <u>5.5</u> PSI	PSI	AFTER 10 MINUTES: _____ W.C.	
	PRESSURE AS LEFT: <u>11.5</u> PSI	PSI	PRESSURE AS LEFT: _____ W.C.	
X	PIPING PRESSURE TEST		INV. TOTAL	<u>1691.76</u>
CUSTOMER SIGNATURE	START	PSIG	FINISH	PSIG
			AMOUNT RECEIVED	

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

Eric Pollock
SERVICE REP. SIGNATURE

09/23/26
DATE

X

CUSTOMER SIGNATURE