

- SALES
- SERVICE
- INSTALLATION

MODERN GAS
THE PROS IN PROPANE SINCE 1954

ENERGY FOR EVERYONE
propane

9:30

Ty / RT

1335 US Hwy 82 W, Leesburg, GA 31763 (229) 435-6116 FAX (229) 435-6119

Order Number 900495	Date Written 8/31/26	Taken By: JC	Schedule Date 9/04/26	Date Completed 9-4-26
Branch - Customer No. 1-21677	Home 229 435-8056	Work	Time Started 9:30 12:40-2:23	Time Completed 10:20
Name SHELLY R DAVIS		Cell	OLD DAWSON, RT N D'BLEGATE LF GATEWAY, LF W D'BLEGATE L DAVENPORT HO ON RT !!PULL FR ST SEE MEMOS!! **H/WATER, LOGS**	
Address 2709 DAVENPORT DR City ALBANY, GA 31721		Zip		
Service Address 2709 DAVENPORT DR ALBANY, GA 31721				
Work to be performed: DELIVER & INSTALL GE 50 GALLON LP WATER HEATER PER MS DAVID; CALL MS DAVIS @ 678-372-9962 WHEN ON THE WAY			Work completed Swapped out tank type water heater	

Qty:	Materials	Price	Amount	Qty:	Materials	Price	Amount
15"	Pex		2.1	1	WT. GP50T08BXR		786.1
2	Pex elbows		9.72				
1	Pex coupling		3.26	16	P08		28.49
10	Pex rings		4.50				
2	3/4" Pex FIP		9.48				
2	3/4" Pex MIP		13.34				
1	Shark bite elbow		20.19				

DR. RT.	Rt. Seq.	Rate	Deposit
Tank Make	Size 61	Serial 25A037093	Tank Percent
Single Stage	Regular Date	Reg. Condition	Mfr. Model Vent Pos. Protected?
TWO 1st			
STAGE 2nd			

Less Check		Flow Check		Lock-up Check	
Manometer Reading at Start 10	Manometer Reading After 10 minutes 10	Manometer Reading Under Load	Manometer Reading	SHOP OR TRUCK SUPPLIES 16.50	
Central Heating	Water Heater	Range	Clothes Dryer	MATERIAL TOTAL 893.48	
Manufacturer GE				TRIP CHARGE	
Model No. GP50T08BXR01				LABOR 340.00	
Serial No. RA602576C				SUB-LABOR Rebate <200.00>	
Sed. Trap	Vent			PERMIT	
Fuel/BTU 000 36 000	N/A	N/A	000	SHIPPING/FREIGHT	
AGE				Thank You	
Shut off Installed				SALES TAX 21.48	

☐ CASH ☐ CHECK		RECEIVED BY Ty + Ryan		Date 9/4/26	
Work Completed by:		Customer Signature Shelly R. Davis		Date 9/4/26	
I ACKNOWLEDGE THAT I HAVE READ AND UNDERSTAND THE IMPORTANT SAFETY INSTALLATION INFORMATION PRINTED ON BACK OF THE CUSTOMER COPY					

ANY UNUSED GAS PIPING OUTLETS INDOORS?	☐ YES ☐ NO
IF YES, IS EACH UNUSED GAS PIPING OUTLET FITTED WITH A GAS TIGHT THREADED PLUG OR CAP?	☐ YES ☐ NO
CUSTOMER AVAILABLE	☐ YES ☐ NO
CUSTOMER SMELLED ODORIZED PROPANE AND SHOWN THE SHUTDOWN PROCEDURE	☐ YES ☐ NO