

INVOICE

FITZGERALD WATER LIGHT AND BOND
P.O. Box 667
FITZGERALD, GA 31750

(229) 426-5400

TO: HANK COOK
PO BOX 5510
FITZGERALD, GA 31750

INVOICE NO: 58084
DATE: 8/25/26

CUSTOMER NO: 3792/3868

TYPE: RW - Residential Wilcox Co

QUANTITY	DESCRIPTION	UNIT PRICE	EXTENDED PRICE
1.00	MDSE - Appliances SER #WD UA 039012 Inventory item selected for charge code: AP-60000163021 Quantity: 1.00 351-RE199EP	1,414.97	1,414.97
1.00	MDSE - Appliances Inventory item selected for charge code: AP-60000163011 Quantity: 1.00 PIPE COV ENCL 4 R75L	187.13	187.13
1.00	MDSE - Appliances Inventory item selected for charge code: AP-60000163032 Quantity: 1.00 PLUMBING INSTALLATION KIT	75.38	75.38
1.00	Sales Tax	134.20	134.20

TOTAL DUE: \$1,811.68

PLEASE DETACH AND SEND THIS COPY WITH REMITTANCE

DATE: 8/25/26 DUE DATE: 9/04/26
CUSTOMER NO: 3792/3868

NAME: COOK, HANK
TYPE: RW - Residential Wilcox Co

REMIT AND MAKE CHECK PAYABLE TO:
FITZGERALD WATER LIGHT AND BOND
P.O. Box 667
FITZGERALD GA 31750

INVOICE NO: 58084
TERMS: NET 10 DAYS

AMOUNT:

GA
Rebate
\$1,811.68
- 200.00
1611.68

Account Number 3792

Name Hank Cook

Address 1477 Copperhead Rd
Rockelle, GA

Call

Date:

8/12/26

Date

Requested:

9/1/26

Instructions:

Set tank - mount water
& run line to stove & generator

Telephone Office: _____ Home: _____

Appliance Check Item:	Central Heating 1	Space Heater 2	Water Heater 3	Range 4	Clothes Dryer 5	6	7
Manufacturer			Rinnai			General	General
Model No.			RE 199e			G0072900	
Serial No.			WD. UA-139012			3018656004	
Location			Exterior			Exterior	
BTU	000	000	199 000	N/A	N/A	000	330 000
Age			New				gd
Manual Shutoff (Installed/Existing)			installed				installed
Venting			gd				gd

TANK/CYLINDER 582C

SIZE	SERIAL NUMBER	MFR.	MFR. DATE	Last Test Date	Location	Tank Cond.	Paint	Pigtail	Fittings	Gauge	Relief Valve			Fittings Leak Test
											Cond.	Date	Cap	
500	2SE012989	PW	1994	8/24/26	Exterior	gd	gd	new	gd	gd	gd	-	gd	5min

PIPING/REGULATOR OPERATION/CONDITION

SINGLE STAGE		PIPING		REGULATOR DATE CODE	REGULATOR CONDITION	MFR.	MODEL	REG. VENT POSITION	HOW PROTECTED	FLOW PRESSURE
		MATERIAL	SIZE							
		copper	1/2	03/26	new	Regg	LV404T996	Level	Dome	13 IN. WC
TWO STAGE	1ST	copper	1/2	08/25	new	Regg	LV403B66	Level	overhang	10 PSIG
	2ND	copper	1/2	08/25	new	Regg	LV403B66	Level	overhang	10 IN. WC

SYSTEM LEAK TEST

SYSTEM LEAK TEST

SINGLE STAGE	Start Pressure	End Pressure	Time Held	System OK
	(Inches W.C.) 13	(Inches W.C.) 13	5min	✓ OK
TWO STAGE	1ST	(PSIG)		
	2ND	(Inches W.C.)	(Inches W.C.)	

Comments: _____

This inspection covers (propane/LP-Gas) items and equipment visible and accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal working of sealed equipment, or structural components, and cannot be construed to cover future defects or unforeseen happenings.

Reference Invoice No. WFA568402

Date

9/1/26
(Mo. Day Yr.)

I, Emmy HARRIS
(Please Print)

- Know how to turn off gas in case of emergency.
- Have smelled propane and can detect its odor.
- Have received the Consumer Safety Information.
- Had gas system deficiencies and / or corrections, if any, clearly explained to me.
- Am satisfied with the service work performed.

I, Chris Woods
(Please Print)

Certify that I have completed the System Check as prescribed

Performed Odor Test ☒ Yes

Performed Pressure Test ☒ Yes
Left Consumer Safety Info ☒ Yes

Chris Woods
Delivery Man / Technician Signature