

1st Call

25

1335 US Hwy 82 W, Leesburg, GA 31763 (229) 435-6116 FAX (229) 435-6119

Order Number 901318	Date Written 9/23/26	Taken By MEH	Schedule Date 9/23/26	Date Completed 9/23/26
Branch - Customer No. 1-37559	Home 229 881-6060	Work	Time Started 9:30 A.M.	Time Completed 11:20 P.M.
Name HARVEY JORDAN FARMS #1	Address MRS JEAN WEBB HOUSE	Cell	CROSS RXR IN LEARY GO APX 4 MI, 1ST WOOD FRAME HO PST POND ON LFT WHITE PICKET FENCE**HW & HEAT** 500 NEXT TO BARN	
City LEARY, GA	Zip 39862-0399			
Service Address 7813 GA HWY 37	LEARY, GA 39862-3127			

Work to be performed:

NO HOT WATER. CALLED IN BY WESLEY WEBB.
229-344-3143 CELL:

"No Power" 05 1285

Work completed:
Swap out water heater
with New RL94.
operation normal
up Copy

Qty:	Materials	Price	Amount	Qty:	Materials	Price	Amount
1	10' Vent pipe 224051	40.-		9	3/4 Rex Rings		4.05
1	45' Elbow	70.-		3	3/4 Rex male connector		20.01
1	11.5" out side vent			3	3/4 Rex coupling		9.78
					Rinnai RL94i P.C.A-053159		
				1	WR RL94i:P		1,192.-

DR. RT.		Rt. Seq.		Rate		Deposit	
Tank Make	Size	500	Serial No.	H9074		Tank Percent	
Single Stage	Regular Date	Reg. Condition	Mfr.	Model	Vent Pos.	Protected?	
TWO 1st							
STAGE 2nd							

Less Check		Flow Check		Lock-up Check	
Manometer Reading at Start 9.3	Manometer Reading After 10 minutes 9.3	Manometer Reading Under Load	Manometer Reading		

Central Heating	Water Heater	Range	Clothes Dryer
Manufacturer	Rinnai		
Model No.	RL94iP		
Serial No.	P.C.A-053159		
Sed. Trap	Vent		
Fuel/BTU	000	199	000
AGE	New	N/A	N/A
Shut off Installed			

☐ CASH ☐ CHECK		RECEIVED BY _____ Date 9/23/26	
Work Completed by: _____ Customer Signature: _____ Date 9/23/26		ANY UNUSED GAS PIPING OUTLETS INDOORS? ☐ YES ☐ NO IF YES, IS EACH UNUSED GAS PIPING OUTLET FITTED WITH A GAS TIGHT THREADED PLUG OR CAP? ☐ YES ☐ NO CUSTOMER AVAILABLE ☐ YES ☐ NO CUSTOMER SMELLED ODORIZED PROPANE AND SHOWN THE SHUTDOWN PROCEDURE ☐ YES ☐ NO	