



INVOICE

11421 ✓

HOME OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

NAME	<u>Bonatley Marris</u>	ACCOUNT NO.	
MAIL ADDRESS	<u>96 Brandon Street</u>	DATE ORDERED	
CITY/STATE/ZIP	<u>Baxley GA 31513</u>	☐ CREDIT PROMISED	
PHONE	<u>912-288-6308</u>	DATE COMPLETED	<u>7-17-26</u>
LOCATION		TERMS	

INSTRUCTIONS mount water heater

QTY.	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
1	Rinnai RE180e tankless water heater w/ isolation valves, serial # SEUA-070300		1285 00
2	3/4" pex male adapter	2 89	5 78
1	1/2" cut off valve		16 95
1	1/2" x 3/4" female adapter		3 19
1	1/2" flex pipe		3 99

SERVICEMAN TO COMPLETE IN
PRESENCE OF CUSTOMER:1) STORAGE SYSTEM INSTALLED
IN COMPLIANCE WITH N.F.P.A.
PAMPHLET NUMBER 58 ☐2) ALL APPLIANCES INSTALLED IN
COMPLIANCE WITH N.F.P.A.
PAMPHLET NUMBER 54 ☐

SERVICES PERFORMED

mounted tankless
water heaterTOTAL
MATERIAL

1314 91

TOTAL TIME HOURS

LABOR

120 00

THE ODOR CHARACTERISTICS HAVE
BEEN DEMONSTRATED TO ME.

SERVICES PERFORMED

BY [Signature]

SUBTOTAL

SALES TAX

105 19

X

CUSTOMER'S SIGNATURE

TOTAL DUE

1540 10

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

INSTALLATION OR TURN ON	REMOVAL OR TURN OFF	LEAK AND PRESSURE TEST	
		HIGH	LOW
SIZE:	SIZE:	START LOCK UP:	START LOCK UP:
S/N:	S/N:	TANK OFF PRESSURE:	TANK OFF PRESSURE:
GALLONS OR READING:	GALLONS OR READING:	AFTER 10 MINUTES PRESSURE AS LEFT:	AFTER 10 MINUTES PRESSURE AS LEFT:

AMOUNT RECEIVED \$	
RECEIVED BY	
DATE	
SERVICES RECEIVED BY	

WHITE/CUSTOMER'S COPY; YELLOW/POSTING COPY; PINK/FILE COPY

GASCheck - Gas Appliance System Check

Account Name _____ Invoice Number _____ Date 8 / 27 / 26
 Name Brantley Morris Company Sikes Propane, Inc.
 Address 96 Brandon Street Call Taken By _____
 City Baxley State GA Zip 31513 Telephone (Cell) 912-288-6308 (Home) _____

Appliance Check

Appliance	<u>water heater</u>					
Manufacturer	<u>Rinnai</u>					
Model #	<u>RE180a</u>					
Serial #	<u>SE. UA-07 0300</u>					
BTU's	<u>180,000</u>					
Burner / Comb. Chamber	<u>ok</u>					
Man. Shutoff / Sed. Trap	<u>installed</u>					
Control / Pilot Safety System	<u>ok</u>					
Venting System	<u>ok</u>					
Age	<u>new</u>					
Taken Out Of Service Or Operation						

Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
<u>120</u>	<u>25A033570</u>	<u>American W.</u>	<u>1997</u>	<u>ok</u>	<u>ok</u>	<u>09-97</u>	<u>ok</u>

Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held	Work Order
<u>150 psi.</u>	<u>150 psi.</u>	<u>10 min.</u>	<u>⓪</u> N	<u>⓪</u> N

Piping Check

Materials	Size	Cover / Protection
<u>coated copper</u>	<u>1/2"</u>	<u>ok</u>

System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held	Work Order
<u>9 in. wc.</u>	<u>9 in. wc.</u>	<u>10 min.</u>	<u>⓪</u> N	<u>⓪</u> N

Regulator Check

Type	Manufacturer	Date / Model	Vent Position / Protection		
<u>Twin</u>	<u>Rego</u>	<u>02C2025 / LV404B39</u>	<u>u-c</u>		

Safety Information Supplied:

Comments: Please note all repairs and corrections made along with any recommended actions.