



INVOICE

No 11475 ✓

HOME OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

NAME	<u>Tommy Daniels</u>	ACCOUNT NO.	
MAIL ADDRESS	<u>237 Live Oak Ln.</u>	DATE ORDERED	
CITY/STATE/ZIP	<u>Baxley GA 31513</u>	DATE PROMISED	
PHONE	<u>912-278-9672</u>	DATE COMPLETED	<u>9-10-26</u>
LOCATION		TERMS	

INSTRUCTIONS deliver appliances

QTY.	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
1	Frigidaire FRTF1936AV refrigerator, s#KA5510341		699 99
1	Frigidaire FCRG3062ASM gas range, s#VF63457163		899 95
1	Amana NGD4655EW4 gas dryer, s#MF1506391 w/conv. kit		661 00
2	Amana NTW4519JW2 washer, s#CF2701194, s#CF2701166	499	998 00
1	Woods WFF176W refrigerator, s#5224073201038		549 99
1	Washer fill hose kit		17 99
1	Frigidaire GRLP5 conversion kit		29 95
1	30,000. btu Hearthrite HBW30TL-1 blue flame heater		495 00
1	Rinnai RE140e tankless water heater w/isolation valves		1150 00

SERVICEMAN TO COMPLETE IN 6812 3er # WD. 4A-03 SERVICES PERFORMED delivered appliances TOTAL MATERIAL 5501 87

PRESENCE OF CUSTOMER:

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐

2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐

THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.

X CUSTOMER'S SIGNATURE

SERVICER'S PERFORMED

BY Daniel Sikes

TOTAL TIME _____ HOURS

LABOR

SUBTOTAL

SALES TAX 440 15

TOTAL DUE 5942 02

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

INSTALLATION OR TURN ON	REMOVAL OR TURN OFF	LEAK AND PRESSURE TEST	
		HIGH	LOW
SIZE:	SIZE	START LOCK UP	START LOCK UP
S/N:	S/N:	TANK OFF PRESSURE	TANK OFF PRESSURE
GALLONS OR READING:	GALLONS OR READING:	AFTER 10 MINUTES	AFTER 10 MINUTES
		PRESSURE AS LEFT	PRESSURE AS LEFT

AMOUNT RECEIVED \$ _____

RECEIVED BY _____

DATE _____

SERVICES RECEIVED BY _____



HOME OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

INVOICE

NO 11476

NAME	<u>Tommy Daniels</u>	ACCOUNT NO.	
MAIL ADDRESS	<u>237 Live Oak Ln.</u>	DATE ORDERED	
CITY/STATE/ZIP	<u>Baxley GA 31513</u>	DATE PROMISED	
PHONE	<u>912-278-9672</u>	DATE COMPLETED	<u>9-10-26</u>
LOCATION		TERMS	

INSTRUCTIONS run all gas lines, set 120 gallon tank, install appliances

QTY.	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
100	gallon of propane	2 99	299 00
62'	$\frac{3}{8}$ " coated copper tubing	3 29	203 98
13'	$\frac{1}{2}$ " coated copper tubing	3 99	51 87
1	$\frac{1}{2}$ " cut off valve		16 95
3	$\frac{3}{8}$ " cut off valve	12 95	38 85
12	$\frac{3}{8}$ " flare nut	1 50	18 00
6	$\frac{1}{2}$ " flare nut	1 60	9 60
1	$\frac{1}{2}$ " swivel		3 99
3	$\frac{3}{8}$ " x $\frac{1}{2}$ " flare tee	4 99	14 97
All	other gas fittings, straps, pipe fittings, thread sealant		28 20

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER: 1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐ 2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐ THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME. X _____ CUSTOMER'S SIGNATURE	SERVICES PERFORMED <u>Run all gas lines, set 120 gallon tank, installed tankless water heater, space heater, range, gas dryer, converted range & dryer to LP, ran pressure check, lit & checked out appliances</u>	TOTAL MATERIAL	685 41
	TOTAL TIME _____ HOURS	LABOR	780 00
	BY <u>Daniel Sikes</u>	SUBTOTAL	
		SALES TAX	54 83
		TOTAL DUE	1520 24

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE				-GPEA rebate 300.00 AMOUNT RECEIVED \$ 1220.24
INSTALLATION OR TURN ON	REMOVAL OR TURN OFF	LEAK AND PRESSURE TEST		
		HIGH	LOW	
		START LOCK UP	START LOCK UP	
SIZE: <u>120</u>	SIZE	TANK OFF PRESSURE	TANK OFF PRESSURE	
S/N: <u>25A020597</u>	S/N:	AFTER 10 MINUTES	AFTER 10 MINUTES	
GALLONS OR READING: <u>100 gal</u>	GALLONS OR READING:	PRESSURE AS LEFT	PRESSURE AS LEFT	

WHITE/CUSTOMER'S COPY; YELLOW/POSTING COPY; PINK/FILE COPY

GASCheck - Gas Appliance System Check

Account Name _____ Invoice Number _____ Date 9/10/26
 Name Tommy Daniels Company Sikes Propane, Inc.
 Address 237 Live Oak Ln. Call Taken By _____
 City Baxley State GA Zip 31513 Telephone (Cell) 912-278-9672 (Home) _____

Appliance Check

Appliance	water heater	range	dryer	space heater		
Manufacturer	Rinnai	Frigidaire	Amana	Hearthrite		
Model #	RE140e	FCRG3062	NGD4655	H8W307L-1		
Serial #	WD. UA-03 6818	VF63457163	MF1506391	RM2314014 324		
BTL's	140,000	74,000	22,000	30,000		
Burner / Com. Chamber	ok	ok	ok	ok		
Main Shutoff / Sed. Trap	installed	installed	installed	installed		
Control / Pilot Safety System	ok	ok	ok	ok		
Venting System	ok	ok	ok	ok		
Age	new	new	new	new		
Taken Out Of Service Or Operation						

Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
120	2SA020597	American W	1995	ok	ok	SA95	ok

Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held	Work Order
140 psi.	140 psi.	10 min.	☒	☒

Piping Check

Materials	Size	Cover / Protection
coated copper	1/2" + 3/8"	ok

System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held	Work Order
9 in. wc.	9 in. wc.	10 min.	☒	☒

Regulator Check

Type	Manufacturer	Date / Model	Vent Position / Protection
Twin	Rego	08D2025 / LV404B39	n-c

Safety Information Supplied:

Comments: Please note all repairs and corrections made along with any recommended actions.