



INVOICE

11474 ✓

HOME OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

NAME	<u>Dylan Hutchinson</u>	ACCOUNT NO.	
MAIL ADDRESS	<u>3441 Zane Rd.</u>	DATE ORDERED	
CITY/STATE/ZIP	<u>Baxley GA 31513</u>	DATE PROMISED	
PHONE	<u>912-278-3806</u>	DATE COMPLETED	<u>9-8-26</u>
LOCATION		TERMS	

INSTRUCTIONS Run all gas lines, install fire box, gas logs, tankless water heater, & 120 gallon tank

QTY.	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
1	42" Monessen RHF42-H fire box w/ T-stat blowers & liner / herringbone		1065 90
1	30" Highland Oak NB24PV-B gas log w/ 4001TH-A-FW remote		1189 00
1	Rinnai RE199e tankless water heater w/ isolation valves serial # TL-4A-164965		1550 00
88	gallon of propane	1 59	139 92
1	Rego LV3403B4 second stage regulator		59 95
10'	1/2" coated copper tubing	3 99	39 90
55'	3/8" coated copper tubing	3 29	180 95
All	other gas fittings, cut off valves, stud guards, sealant		94 90

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐

SERVICES PERFORMED

Run all gas lines,

TOTAL MATERIAL

4320 52

installed tankless water heater, fire box, gas logs w/ remote, set 120 gallon tank, ran pressure check, lit & checked out appliances

TOTAL TIME _____ HOURS

LABOR

750 00

THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.

SERVICES PERFORMED

BY

Dan Hill

SUBTOTAL

SALES TAX

345 64

X _____
CUSTOMER'S SIGNATURE

TOTAL DUE

5416 16

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

INSTALLATION OR TURN ON	REMOVAL OR TURN OFF	LEAK AND PRESSURE TEST	
		HIGH	LOW
SIZE: <u>120</u>	SIZE	START LOCK UP:	START LOCK UP:
S/N: <u>25A070334</u>	S/N:	TANK OFF PRESSURE:	TANK OFF PRESSURE:
GALLONS OR READING: <u>88 gal</u>	GALLONS OR READING:	AFTER 10 MINUTES	AFTER 10 MINUTES
		PRESSURE AS LEFT:	PRESSURE AS LEFT:

GP&A rebate 200.00
AMOUNT
RECEIVED \$ 5216.16

RECEIVED BY _____
DATE _____
SERVICES RECEIVED BY _____

WHITE/CUSTOMER'S COPY; YELLOW/POSTING COPY; PINK/FILE COPY

GASCheck - Gas Appliance System Check

Account Name _____ Invoice Number _____ Date 9/8/26
 Name Dylan Hutchinson Company Sikes Propane, Inc.
 Address _____ Call Taken By _____
 City Baxley State GA Zip 31513 Telephone (Cell) _____ (Home) 912-326-1862

Appliance Check

Appliance	<u>water heater</u>	<u>Gas Logs</u>				
Manufacturer	<u>Rinnai</u>	<u>Hearth + Home Tech</u>				
Model #	<u>RE199a</u>	<u>NB24PV-B</u>				
Serial #	<u>TLUA-164 965</u>	<u>MP663007 770</u>				
BTL's	<u>199,000</u>	<u>36,000</u>				
Burner / Com. Chamber	<u>ok</u>	<u>ok</u>				
Man. Shutoff / Sed. Trap	<u>installed</u>	<u>installed</u>				
Control / Pilot Safety System	<u>ok</u>	<u>ok</u>				
Venting System	<u>ok</u>	<u>ok</u>				
Age	<u>new</u>	<u>new</u>				
Taken Out Of Service Or Operation						

Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
<u>120</u>	<u>2SA070334</u>	<u>American W.</u>	<u>2004</u>	<u>ok</u>	<u>ok</u>	<u>03-04</u>	<u>ok</u>

Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held	Work Order
<u>135psi.</u>	<u>135psi.</u>	<u>10min.</u>	<u>✓</u>	<u>✓</u>

Piping Check

Materials	Size	Cover / Protection
<u>coated copper</u>	<u>1/2" + 3/8"</u>	<u>ok</u>

System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held	Work Order
<u>9in.wc.</u>	<u>9in.wc.</u>	<u>10min.</u>	<u>✓</u>	<u>✓</u>

Regulator Check

Type	Manufacturer	Date / Model	Vent Position / Protection
<u>First</u>	<u>MEC</u>	<u>19 Dec. 23 / MEGR-1222H-BGF</u>	<u>u-c</u>
<u>Second</u>	<u>Rego</u>	<u>01C2025 / LV3403B4</u>	<u>down</u>

Safety Information Supplied:

Comments: Please note all repairs and corrections made along with any recommended actions.