



INVOICE

No 11492 ✓

HOME OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515

2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

NAME	<u>Eddie Lugo</u>	ACCOUNT NO.	
MAIL ADDRESS	<u>4427 Altamaha School Rd</u>	DATE ORDERED	
CITY/STATE/ZIP	<u>Baxley GA 31513</u>	DATE PROMISED	
PHONE	<u>912-253-2924</u>	DATE COMPLETED	<u>9-24-26</u>
LOCATION	<u>Spec #106</u>	TERMS	

INSTRUCTIONS run gas lines, set 120 gallon tank, install tankless water heater + gas logs

QTY.	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
1	Rinnai RE160 tankless water heater w/ isolation valves, serial # WE.4A-052645		1250 00
1	30" Menasha Highland Oak w/ EW4001TH remote		1199 00
100	gallon of propane	2 99	299 00
18'	1/2" coated copper tubing	3 99	71 82
85'	3/8" coated copper tubing	3 29	279 65
1	1/2" cut off valve		16 95
1	3/8" cut off valve		12 95
4	1/2" flare nut	1 90	7 60
All	other gas fittings, stud guards, thread sealant		50 80

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐

2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐

SERVICES PERFORMED

set 120 gallon tank,

TOTAL MATERIAL

3187 77

run all gas lines, installed tankless water heater + gas logs with remote, run pressure check, lit + checked out appliances

TOTAL TIME _____ HOURS

LABOR

465 00

THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.

SERVICES PERFORMED

BY

[Signature]

SUBTOTAL

SALES TAX

255 02

TOTAL DUE

3907 79

X _____
CUSTOMER'S SIGNATURE

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

INSTALLATION OR TURN ON	REMOVAL OR TURN OFF	LEAK AND PRESSURE TEST		RECEIVED BY _____ DATE _____ SERVICES RECEIVED BY _____
		HIGH	LOW	
SIZE: <u>120</u>	SIZE	START LOCK UP	START LOCK UP	- <u>6P6A</u> rebate <u>200.00</u> AMOUNT <u>3707.79</u>
S/N: <u>2SA029606</u>	S/N	TANK OFF PRESSURE	TANK OFF PRESSURE	
GALLONS OR READING: <u>100 gal</u>	GALLONS OR READING:	AFTER 10 MINUTES	AFTER 10 MINUTES	
		PRESSURE AS LEFT	PRESSURE AS LEFT	

WHITE/CUSTOMER'S COPY, YELLOW/POSTING COPY, PINK/FILE COPY

GASCheck - Gas Appliance System Check

Account Name Spec # 106 Invoice Number _____ Date 9 / 24 / 26
 Name Eddie Lugo Company Sikes Propane, Inc.
 Address 4427 Altamaha School Rd. Call Taken By _____
 City Baxley State GA Zip 31513 Telephone (Cell) 912-253-2924 (Home) _____

Appliance Check

Appliance	<u>water heater</u>	<u>gas Log</u>				
Manufacturer	<u>Rinnai</u>	<u>Hearth + Home Tech.</u>				
Model #	<u>RE160a</u>	<u>NB24PV-B</u>				
Serial #	<u>WEUA-05</u>	<u>MP6630088</u>				
	<u>2645</u>	<u>78</u>				
BTL's	<u>160,000</u>	<u>36,000</u>				
Burner / Comb. Chamber	<u>ok</u>	<u>ok</u>				
Man. Shutoff - Sed. Trap	<u>installed</u>	<u>installed</u>				
Control / Pilot Safety System	<u>ok</u>	<u>ok</u>				
Venting System	<u>ok</u>	<u>ok</u>				
Age	<u>new</u>	<u>new</u>				
Taken Out Of Service Or Operation		<u>30"</u>				

Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
<u>120</u>	<u>2SA029606</u>	<u>American W.</u>		<u>ok</u>	<u>ok</u>	<u>11D96</u>	<u>ok</u>

Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held
<u>120psi.</u>	<u>120psi.</u>	<u>10min.</u>	<u>0</u>
			<u>0</u>
			<u>0</u>

Piping Check

Materials	Size	Cover / Protection
<u>coated copper</u>	<u>1/2" x 3/8"</u>	<u>ok</u>

System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held
<u>9in. wc.</u>	<u>9in. wc.</u>	<u>10min.</u>	<u>0</u>
			<u>0</u>
			<u>0</u>

Regulator Check

Type	Manufacturer	Date / Model	Vent Position / Protection
<u>Twin</u>	<u>Rego</u>	<u>05A2025 / LV404B39</u>	<u>u-c</u>

Safety Information Supplied:

Comments: Please note all repairs and corrections made along with any recommended actions.