

✓ Sum

←

8/27/2026 8:47:44 AM

WORK ORDER

Brandon Mathis

Wilscott Winds Lot #4
Morganton, GA 30560
(706) 455-1238

Customer #: 206380
Order #: 537572
Location #: 282631
Zone: B-012-FRI-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 9/2/26 - Final hook up - Take/Install (2) 24" Palmetto Oak. Hook
up logs, furnace, water heater and convert and hook up stove.
Will need to run yard line. 706-455-1238

made test

Date Ordered: 8/27/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
Name:	Last Service: 7/17/2026		Last Tune Up:	
Contract:	SC Renewal:			
Manufact:	Model:			
Notes:				
Instructions:				

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 206380

Name: BRANDON MATHIS

Address: WILSCOTT WINDS LOT# 4
MORGANTON GA 30560

Date: 9/2/26

FINAL HOOKUP/I(2) 24" PALMETTO OAK HOOK UP
LOGS FURNACE WATER HEATER AND CONVERT AND
HOOK UP STOVE WILL NEED TO RUNYARD LINE

Order #: 537572

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Log Set	Log Set	Water Heater	Hvac	Stove	
Manufacturer	Everwarm	Everwarm	Navian	Bryant	Whirlpool	
Model #	EW2430PR	EW2430PR	NPE-240A2	CVama3617	WSG5453020	
Serial #	10064495	10056474	20320205970	1026526910	RE5110026	
Burner/Combustion Chamber	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
325	MA542407	Good	Triarc	2025	UG	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	Mee	1222H	☒ Correct ☐ Incorrect		
2nd	Fisher	R622E	☒ Correct ☐ Incorrect	11.3	12.3

Piping System Leak Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
100 PSI	100 PSI	10 Mins	☒ Yes	15 PSI	15 PSI	10 Mins	☒ Yes
WC	WC	Mins	☐ No				☐ No

Pressure Test:

Comments:

Customer Acknowledgment: I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	Alvin Wilson	Service Technician (Signature)	[Signature]	Date	9-2-26
Customer (Print)	Brandon Mathis	Customer (Signature)	[Signature]	Date	



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 206380

Name **BRANDON MATHIS**

Address **WILSCOTT WINDS LOT #4**

MORGANTON GA 30560

Date: 7-17-26

Instructions: **DELIVER 325UG W/ 50G @ 2.499 ANODE
BAG 706-455-1238 KN**

Order #: 524414

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check Yes No

Gas check attached Yes No

Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

#

EXP. DATE

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed.
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to year contract for discount.

CUSTOMER SIGNATURE

Retail Price

Contract Price

Rinnai \$

\$

Standard Vent Kit \$

\$

Standard Install \$

\$

Total \$

\$

Tank Set

New Cust Special

L P Gas /Gal 2.999

L P Gas /Gal 2.499

Gallons 50

Gallons 50

FRCC \$9.79

FRCC \$9.79

9.79

Fuel Total 149.95

Fuel Total 129.95

129.95

Tank Lease/YR 129.00

1st yr Lease FREE

FREE

Total Materials

Sub-Total

Sales Tax

Tank Set Fee \$250

Tank Set Fee 20.00

20.00

Safety Inspection \$129.95

\$29.95

29.95

Total Labor

Total charges

Prepay Bal On Account

Safe Appliance Savings

494.78

Safe Appliance Rebate

600.00

TOTAL BALANCE DUE