

✓SUM

8/31/2026 10:42:48 AM

WORK ORDER

Austin Vest

66 Mountain Top Circle
Blue Ridge, GA 30513
(706) 851-5836

Customer #: 206048
Order #: 538015
Location #: 282211
Zone: B-015-FRI-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

9-10-26

Description: ~~09/04/26~~ - HOOK UP TANK - CALL 706-851-5836 - CT

Date Ordered: 8/31/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
-------------------------	-----------------	------------------	--------	-------

Name:

Last Service: 5/8/2026

Last Tune Up:

Contract:

SC Renewal:

Manufact:

Model:

Notes:

Instructions:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 206048

Date: 9/4/26

Name: AUSTIN VEST

Instructions: HOOK UP TANK ANODE TEST CALL

Address: 66 MOUNTAIN TOP CIRCLE

706-851-5836

BLUE RIDGE, GA 30513

Order #: 538115

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	water heater	log set	stove			
Manufacturer	Danfoss	Log set	Panasonic			
Model #	RTGR199X1	NV	25060035			
Serial #	P220002496	NV	FFSG56197			
Burner/Combustion Chamber	☒ Ok	☒ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☒ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☒ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
500	M2633722	Good	Trane	2026	UG	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	Rego	LV3403TR9	02/2026	☒ Correct ☐ Incorrect	
2nd	Rego	LV340364	01/2026	☒ Correct ☐ Incorrect	12.1

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
100 PSI	190 PSI	10 Mins	☒ Yes	15 PSI	15 PSI	10 Mins	☒ Yes
WC	WC	Mins	☐ No				☐ No

Comments:

Customer Acknowledgment:

I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	Brandon Payne	Service Technician (Signature)	[Signature]	Date	9-10-26
Customer (Print)		Customer (Signature)		Date	



P.O. Box 2155
2955 Appalachian Highway
Blue Ridge, Georgia 30513
706-632-7606
www.folgergas.com

UNDERGROUND CATHODIC TESTING

Customer Acct # 206048

Date: 9/4/26

Name: AUSTIN VEST

Instructions: ANODE TEST

Address: 66 MOUNTAIN TOP CIRCLE

BLUE RIDGE, GA 30513

538015


Size	Serial #	MFR.	MFR. Date	Last Test Date	Location	Tank Cond	Paint Cond	Pigtail Cond	Fittings Cond	Gauge Cond	Relief Valve			Fittings Leak Test
											Cond	Date	Cap	
500	M2633722	Trane	2026	9/10/26	UG	Good	Good	Good	Good	Good	Good	Good	Good	Good

The owner of the tank will be responsible for having the tank tested and must pass in order to be put into service. The tank will then have to be retested in 12 months and 36 months thereafter, as per code section 6.6.6.1-K in the NFPA 58.

TANK READING

-1.32

D. C. Volts



-1.25

D. C. Volts

Pass or Fail Pass

Date of Service 9/10/26

Comments _____

[Signature]
Service Tech Signature

Owners Signature



INVOICE

Customer #:	206048
Payment Terms:	Net 30
Invoice #:	538015
Invoice Date	2026-09-10
Total Due	\$0.00

Austin Vest
66 Mountain Top Circle
Blue Ridge, GA 30513

Make Check Payable to: Folger Gas, LLC

Amount Enclosed: \$ _____

Remit To:
Folger Gas, LLC
PO BOX 2155
Blue Ridge, GA 30513

Customer Name		Delivery/Service Address		Cust #	Invoice #	Inv Date
Austin Vest		66 Mountain Top Circle - Blue Ridge, GA 30513		206048	538015	2026-09-10
Quantity	Item Number	Description	Unit Price		TOTAL	
2.50	Labor	Labor	\$100.0000		\$250.00	
18.00	12R50	1/2" COPPER TUBING	\$6.0000		\$108.00	
15.00	TR1	TRENCHING	\$1.5000		\$22.50	
3.00	3708	1/2" FLARE NUTS	\$3.7500		\$11.25	
1.00	Shop Supplies	Shop Supplies	\$19.6000		\$19.60	
1.00	Labor	Labor	\$0.0000		\$0.00	
		Fannin County Tax:			\$4.85	
		GA State Sales Tax:			\$6.45	

Tank/Equipment: Heating System -

For Fuel or Service At:

66 Mountain Top Circle - Blue Ridge, GA 30513

Sub Total	\$411.35
Charges	\$0.00
Tax Total	\$11.30

Your credit card will be charged on 09/10/2026			\$422.65
ACCOUNT BALANCE	\$0.00	TOTAL DUE	\$0.00

09/10/2026 - Technician: Brandon Payne - Work Performed: - Connected yard line to underground tank and installed monitor performed leak test at 100psi for 10mins no leaks 6% bp jd

Folger Gas, LLC
PO BOX 2155
Blue Ridge, GA 30513
706-632-7606
www.folgergas.com