

✓ SUM

8/31/2026 10:42:48 AM

WORK ORDER

Austin Vest

66 Mountain Top Circle
Blue Ridge, GA 30513
(706) 851-5836

Customer #: 206048
Order #: 538015
Location #: 282211
Zone: B-015-FRI-
Terms: Net 30

Tech: _____

Map Code:
Service Code: Propane Service *9-10-26*
Description: ~~09/04/26~~ - HOOK UP TANK - CALL 706-851-5836 - CT

Date Ordered: 8/31/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
-------------------------	-----------------	------------------	--------	-------

Name:	Last Service: 5/8/2026	Last Tune Up:
Contract:	SC Renewal:	
Manufact:	Model:	
Notes:		
Instructions:		

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 206048

Date: 9/4/26

Name: AUSTIN VEST

Instructions: HOOK UP TANK ANODE TEST CALL

Address: 66 MOUNTAIN TOP CIRCLE

706-851-5836

BLUE RIDGE, GA 30513

Order #: 538115

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	water heater	log set	stove			
Manufacturer	Danfoss white	cannon 6911	Paro			
Model #	RTGR199X1	NV	25060035			
Serial #	P220002496	NV	FFS G56197			
Burner/Combustion Chamber	☒ Ok	☒ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☒ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☒ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
500	M2633722	Good	Trigac	2026	UG	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	Rego	LV3403TR9	02/2026	☒ Correct ☐ Incorrect	
2nd	Rego	LV340364	01/2026	☒ Correct ☐ Incorrect	12.1

Piping System Leak Test:**Pressure Test:**

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
100 PSI	190 PSI	10 Mins	☒ Yes	15 PSI	15 PSI	10 Mins	☒ Yes
WC	WC	Mins	☐ No				☐ No

Comments:

Customer Acknowledgment: I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print) Brandon Payne	Service Technician (Signature)	Date 9-10-26
Customer (Print)	Customer (Signature)	Date



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 206048

Name AUSTIN VEST

Address 66 MOUNTAIN TOP CIRCLE

BLUE RIDGE, GA 30513

Date: 9/2/26

Instructions: DROP 500UG W/50G@2.999. DROP ANODE
PICK UP 500AG W/MONITOR. CALL 706-851-5836 CCOF

Order #: 538014

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check Yes No

Gas check attached Yes No

Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

#

EXP. DATE

* I have received the Consumer Safety information & material.

* I am satisfied with the work performed.

* Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.

* Signing agrees to year contract for discount.

CUSTOMER SIGNATURE

Retail Price

Contract Price

Rinnai \$	\$
Standard Vent Kit \$	\$
Standard Install \$	\$
Total \$	\$

Tank Set

New Cust Special

L P Gas /Gal 2.999	L P Gas /Gal 2.999
Gallons 50	Gallons 50
FRCC \$9.79	FRCC \$9.79
Fuel Total 149.95	Fuel Total 149.95
Tank Lease/YR 129.00	1st yr Lease 129.00
Total Materials	
Sub-Total	
Sales Tax	
Tank Set Fee \$250	Tank Set Fee FREE
Safety Inspection \$129.95	\$29.95
Total Labor	
Total charges	
Prepay Bal On Account	

Safe Appliance Savings

Safe Appliance Rebate

TOTAL BALANCE DUE