

8/12/2026 3:42:15 PM

WORK ORDER

Heather Baldwin

101 Nellies Big Fish Road
Suches, GA 30572
(843) 252-7191

Customer #: 206529
Order #: 535228
Location #: 282804
Zone: B-007-WEE-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 08/18/2026 - GO 1ST! - T/I 250AG W/200G@2.499G RUN
YARD LINE. RUN LINE TO W/HEATER. HOOK UP W/H AND
STOVETOP. LINE THERE & ALREADY CONVERTED - CALL
REX 843-252-1346 - CCOF - CT

Date Ordered: 8/12/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
Name:	Last Service:	Last Tune Up:		
Contract:	SC Renewal:			
Manufact:	Model:			
Notes:				
Instructions:				

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 206529

Date: 8/18/26

Name: HEATHER BALDWIN

Instructions: GO 1ST! T/I 250AG W/200G@2.499G RUN YD

Address: 101 NELLIES BIG FISH ROAD

LINE. RUN LIN TO W/H AND HOOK UP AND HOOK UP
STOVETOP. LINE THERE & ALREADY CONVERTED CALL

SUCHES, GA 30572

Order #: 535228 REX 843-252-1346 CCOF

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Water Heated					
Manufacturer	Navien					
Model #	NPE-150S2000					
Serial #	2075Z2542969C22					
Burner/Combustion Chamber	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
2.50	M2272613	Good	ARLOSA	2022	AC	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	Rexo	LV3403TR9	10/24	☒ Correct ☐ Incorrect	
2nd	Rexo	LV3403B4	4/25	☒ Correct ☐ Incorrect	11.3

Piping System Leak Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
110 PSI	110 PSI	10 Mins	☒ Yes	15 PSI	15 PSI	10 Mins	☒ Yes
WC	WC	Mins	☐ No				☐ No

Pressure Test:

Comments: Owner Plumber will convert Navien w/H.

Customer Acknowledgment:

- I acknowledge, by checking each of the following items, that:
- ☒ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
 - ☒ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
 - ☒ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
 - ☒ I have smelled propane gas and can detect its odor.
 - ☒ I have been told to consider installing one or more gas detectors.
 - ☒ I have received safety information and told to read it and share it with all family members.
 - ☒ I am satisfied with the service work performed.

Service Technician (Print) Reginald S. Sardo	Service Technician (Signature) 	Date 8/18/26
Customer (Print) Heather Baldwin	Customer (Signature) 	Date



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 206529
Name HEATHER BALDWIN
Address 101 NELLIES BIG FISH ROAD
SUCHES, GA 30572

Date: 8/18/26
Instructions GO 1ST! T/I 250W/200G82.499G RUN YD LI
RUN LINE TO W/H AND HOOK UP AND STOVETOP. LINE TI
THERE & ALREADY CONVERTED. CALL REX 843-252-1346.
Order #: 535228 CCOF

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check ☐ Yes ☐ No
Gas check attached ☐ Yes ☐ No
Leak check Initial _____

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK # _____

☐ CREDIT CARD

EXP. DATE _____

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed.
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to _____ year contract for discount.

CUSTOMER SIGNATURE

Retail Price		Contract Price
Rinna \$		\$
Standard Vent Kit \$		\$
Standard Install \$		\$
Total \$		\$
Tank Set		New Cust Special
L.P. Gas /Gal	2.999	L.P. Gas /Gal 2.499
Gallons	200	Gallons 200
FRCC	\$9.79	FRCC \$9.79
Fuel Total	599.80	Fuel Total 499.80
Tank Lease/	99.00	1st yr Lease FREE
Total Materials		
Sub-Total		
Sales Tax		
Tank Set Fee	\$250	Tank Set Fee 20.00
Safety Inspection \$129.95		\$29.95
Total Labor		
Total charges		
Prepay Bal On Account		
Safe Appliance Savings		648.86
Safe Appliance Rebate		200.00
TOTAL BALANCE DUE		