

8/3/2026 8:12:25 AM

WORK ORDER

Charles Anderson

590 Winding Ridge
Blairsville, GA 30512
(706) 889-4756

Customer #: 206196
Order #: 531242
Location #: 282414
Zone: B-018-MON-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 8/6/26 Final hook. Call 706-889-4756 Email Invoice - CLT

Date Ordered: 8/3/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
------------------------	-----------------	------------------	--------	-------

Name:

Contract:

Manufact:

Notes:

Instructions:

Last Service: 7/6/2026

SC Renewal:

Model:

Last Tune Up:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 206196

Date 8/6/25

Name: CHARLES ANDERSON

Instructions: FINAL HOOK EMAIL INVOICE - CLT

Address: 590 WINDING RIDGE

Order #: 531242

BLAIRSVILLE GA 30512

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Water Heater	Fire Place				
Manufacturer	Rinnai	Hest 912W				
Model #	RXP149	4132-LP-56				
Serial #	TJ.BA-21161	LC 6479158				
Burner/Combustion Chamber	☒ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
500	M2601128	Good	TRIARC	2026	LG	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	Mec	1222H	☒ Correct ☐ Incorrect		
2nd	R200	Lv4403B66	☒ Correct ☐ Incorrect	11.3	12.2

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
12.0 PSI	12.5 PSI	10 Mins	☒ Yes	15 PSI	15 PSI	10 Mins	☒ Yes
WC	WC	Mins	☐ No				☐ No

Comments:

Customer Acknowledgment: I acknowledge, by checking each of the following items, that

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	Service Technician (Signature)	Date
Charles Anderson	[Signature]	8-6-25
Customer (Print)	Customer (Signature)	Date
	Customer not Present	

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
	8:30	10:30	1.5 HR 2	100.00/hr	INCLUDED IN CONTRACT PRICE
FOR OFFICE USE ONLY					
Performed leak check	Yes	No	Retail Price	Contract Price	
Gas check attached	Yes	No	RXP199	\$2992.00	\$2799.95
Leak check	Initial			\$957.95	\$0.00
				\$500.00	\$0.00
				\$4449.95	\$2799.95
					2799.95
Start Pressure	End Pressure	Time Left	Tank Set	New Cust Special	
% in Tank					
AMOUNT REC'D					
\$					
☐ CASH	☐ CHECK #				
☐ CREDIT CARD					
#					
EXP DATE					
I have received the Consumer Safety information material.					
I am satisfied with the work performed.					
Customer agrees to pay all costs of collection agency fees court costs, and reasonable attorney fees in the event of default on payment.					
Signing agrees to 3 year warranty for tank unit.					
Safe Appliance Rebate					1650.00
					400.00
TOTAL BALANCE DUE					3131.33