

WORK ORDER

BRIAN DITTMAN

303 Indian Trail
McCaysville, GA 30555
(706) 455-2999

Customer #: 23688
Order #: 543402
Location #: 252606
Zone: B-002-MON-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 9-9-26 Convert and connect stove 706- 455-2999 COD Sm

Date Ordered: 9/2/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
------------------------	-----------------	------------------	--------	-------

Name: Heating System

Last Service: 8/17/2026

Last Tune Up:

Contract:

SC Renewal:

Manufact:

Model:

Notes:

Instructions:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 23688

Name: BRIAN DITTMAN

Address: 303 INDIAN TRAIL

MCCAYSVILLE GA 30555

Date: 9/9/26

Instructions: CONVERT AND CONNECT STOVE
CALL 706-455-2999 COD-SM

Order #: 543402

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Stove					
Manufacturer	Samsung					
Model #	NX60A6511SS/AA					
Serial #	054U70AL600469R					
Burner/Combustion Chamber	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Manual Shutoff	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Pilot Safety System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
325	1H22067	Good	American	1985	AL	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	Fisher	R12214	☒ Correct ☐ Incorrect		
2nd	Elco	340354	☒ Correct ☐ Incorrect	11.8	13.3

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
110 PSI	110 PSI	10 Mins	☒ Yes ☐ No				☐ Yes ☐ No
WC	WC	Mins		PSI	PSI	Mins	

Comments:

Customer Acknowledgment:

I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	Service Technician (Signature)	Date
Customer (Print)	Customer (Signature)	Date



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 23648
Name Brian Dittman
Address 303 Indian Trail
McClaysville GA 30555

Date: 8-17-26
Instructions: T/I 7.5 Rinnai
Run lines & Connect
Order #: 536172

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check ☐ Yes ☐ No
Gas check attached ☐ Yes ☐ No
Leak check Initial ☐

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

#

EXP. DATE

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed.
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to _____ year contract for discount.

CUSTOMER SIGNATURE

Retail Price

Contract Price

7.5 Rinnai	\$ 164.95	\$ 1299.95	
Standard Vent Kit	\$ 180.00	\$ 0.00	
Standard Install	\$ 230.00	\$ 0.00	
Total	\$ 2499.95	\$ 1299.95	1299.95

Tank Set

New Cust Special

L.P. Gas /Gal		L.P. Gas /Gal	
Gallons		Gallons	
FRCC	\$9.79	FRCC	\$9.79
Fuel Total		Fuel Total	
Tank Lease/YR		1st yr Lease	
Total Materials			
Sub-Total			
Sales Tax			
Tank Set Fee	\$250	Tank Set Fee	
Safety Inspection	\$129.95		\$29.95
Total Labor			
Total charges			
Prepay Bal On Account			

Safe Appliance Savings 1200.00
Safe Appliance Rebate 50.00

TOTAL BALANCE DUE