

✓SUM

9

9/14/2026 9:34:45 AM

WORK ORDER

Charles Anderson

27 Sterling Bridge Road - Lot 112 Owen
Glenn
Blairsville, GA 30512
(706) 889-4756

Map Code:

Service Code: Propane Service

Description: 9/16/26 Connect to tank and house lines are already there Call
706-889-4756 email invoice - clt

Customer #: 206164
Order #: 545122
Location #: 282370
Zone: B-003-MON-
Terms: Net 30

Tech: _____

Date Ordered: 9/14/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
--------------------------------	------------------------	-------------------------	---------------	--------------

Name:

Last Service: 8/14/2026

Last Tune Up:

Contract:

SC Renewal:

Manufact:

Model:

Notes:

Instructions:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 206164

Date: 9/16/24

Name: CHARLES ANDERSON

Instructions: CONNECT TO TANK AND HOUSE

Address: 27 STERLING BRIDGE ROAD LOT 112 OWEN GLEN EMAIL INVOICE LINES THERE CLT

BLAIRSVILLE GA 30512

Order #: 545122

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Water Heater	Logset	Logset			
Manufacturer	Rinnai	Heat Glo	Heat Glo			
Model #	RXP149	SL-5-1PT	SL-5-1PT			
Serial #	TJ.Ba-211692	NV	NV			
Burner/Combustion Chamber	☐ Ok	☒ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☐ Ok	☒ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☐ Ok	☒ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
325	M254213	Good	Rinnai	2025	Log	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	Mec	1222 H	☒ Correct ☐ Incorrect		
2nd	Mec	1222	☒ Correct ☐ Incorrect	11.1	12.4

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
130 PSI	130 PSI	10 Mins	☒ Yes	15 PSI	15 PSI	10 Mins	☒ Yes
WC	WC	Mins	☐ No				☐ No

Comments:

Customer Acknowledgment: I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	Service Technician (Signature)	Date
Alvin Wilcox	[Signature]	9-16-24
Customer (Print)	Customer (Signature)	Date
Customer not present	[Signature]	



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 206164

Name CHARLES ANDERSON

Address 27 STERLING BRIDGE ROAD

BLAIRSVILLE GA 30512

Date: 8/14/26

Instructions T/I RXP199 LINES THERE EMAIL INVOICE
CLT

Order #: 535163

DESCRIPTION OF WORK

COMMENTS: Installed RXP199 w/H.

SERVICED BY: BP/FS

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
<u>8/14/26</u>	<u>9am</u>	<u>10:30am</u>	<u>1.5HR</u>	<u>100.00</u> ~~100.00~~ /hr	<u>150.00</u>
				<u>100.00</u> ~~100.00~~ /hr	<u>150.00</u>

FOR OFFICE USE ONLY

Performed leak check Yes No

Gas check attached Yes No

Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank 80

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

EXP. DATE

* I have received the Consumer Safety information & material.

* I am satisfied with the work performed.

* Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.

* Signing agrees to 3 year contract for discount.

CUSTOMER SIGNATURE

Retail Price		Contract Price	
RXP199 Rinnai	\$ 2992.00	\$ 2799.95	
Standard Vent Kit	\$ 957.95	\$ 0.00	
Standard Install	\$500.00	\$ 0.00	
Total	\$4449.95	\$ 2779.95	2799.95
Tank Set		New Cust Special	
L P Gas /Gal		L P Gas /Gal	
Gallons		Gallons	
FRCC	\$9.79	FRCC	\$9.79
Fuel Total		Fuel Total	
Tank Lease/YR		1st yr Lease	
Total Materials			
Sub-Total			2799.95
Sales Tax			196.00
Tank Set Fee	\$250	Tank Set Fee	
Safety Inspection	\$129.95		\$29.95
Total Labor			0
Total charges			
Prepay Bal On Account			
Safe Appliance Savings			1650.00
Safe Appliance Rebate			400.00
TOTAL BALANCE DUE			2999.95