

✓SUM

9/14/2026 9:32:51 AM

WORK ORDER

Charles Anderson

443 Paradise Lane
Blairsville, GA 30512
(706) 889-4756

Customer #: 206053
Order #: 545121
Location #: 282219
Zone: B-018-MON-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 9/16/26 Connect to tank and house line is already ran Call 706
889 4756 email invoice clt

Date Ordered:	Scheduled Date:	Est. Completion:	Start:	Stop:
9/14/2026				
Name:	Last Service: 8/17/2026	Last Tune Up:		
Contract:	SC Renewal:			
Manufact:	Model:			
Notes:				
Instructions:				

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 206053

Date: 9/16/26

Name: CHARLES ANDERSON

Instructions: CONNECT TO TANK AND HOUSE

Address: 443 PARADISE LANE

LINES THERE EMAIL INVOICE CLT

BLAIRSVILLE GA 30512

Order #: 545121

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Log Set	Log Set	Log Set	Water Heater		
Manufacturer	Heat Glo	Heat Glo	Heat Glo			
Model #	SL-5-IFT	SL-5-IFT	SL-5-IFT	RXP199		
Serial #	NV	NV	NV	TJ. BA-211693		
Burner/Combustion Chamber	☒ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
320	M2605043	Good	Triarc	2026	ug	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	Coragna	984HP-04	☒ Correct ☐ Incorrect		
2nd	MCC	1222	☒ Correct ☐ Incorrect	11.2	13.1

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
140 PSI	140 PSI	10 Mins	☒ Yes	15 PSI	15 PSI	10 Mins	☒ Yes
WC	WC	Mins	☐ No				☐ No

Comments:

Customer Acknowledgment: I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	Service Technician (Signature)	Date
Customer (Print)	Customer (Signature)	Date



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 206053

Date: 8/14/26

Name **CHARLES ANDERSON**

Instructions: T/I RXP199 LINE THERE EMAIL INVOICE

Address 443 PARADISE LANE

BLAIRSVILLE GA 30512

Order #: 535162

DESCRIPTION OF WORK

COMMENTS: *Installed RXP199*

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
8/14/26	12:30	2:00	1.5HR	100.00XXXX/hr	INCLUDED IN
				100.00XXXX/hr	CONTRACT

FOR OFFICE USE ONLY

Performed leak check Yes No

Gas check attached Yes No

Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

#

EXP. DATE

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed.
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to 3 year contract for discount.

CUSTOMER SIGNATURE

Retail Price		Contract Price
RXP199 Rinnai	\$ 2992.00	\$ 2799.95
Standard Vent Kit	\$ 57.95	\$ 0.00
Standard Install	\$ 500.00	\$ 0.00
Total	\$ 4449.95	\$ 2799.95
Tank Set		New Cust Special
L P Gas /Gal		L P Gas /Gal
Gallons		Gallons
FRCC	\$9.79	FRCC \$9.79
Fuel Total		Fuel Total
Tank Lease/YR		1st yr Lease
Total Materials		
Sub-Total		2799.95
Sales Tax		196.00
Tank Set Fee \$250		Tank Set Fee
Safety Inspection \$129.95		\$29.95
Total Labor		
Total charges		
Prepay Bal On Account		
Safe Appliance Savings		1650.00
Safe Appliance Rebate		400.00
TOTAL BALANCE DUE		2995.95