

9/16/2026 3:29:35 PM

WORK ORDER

Peggy Davis

120 Rogers Ln.
Blairsville, GA 30512
(404) 444-5454

Customer #: 206361
Order #: 545756
Location #: 282606
Zone: B-019-MON-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 9/17/26 T/I 250AG W/200G @2.499 All Lines There Call
404-316-6937 Customer paying by check will be onsite-SLM

Date Ordered: 9/16/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
Name:	Last Service:	Last Tune Up:		
Contract:	SC Renewal:			
Manufact:	Model:			
Notes:				
Instructions:				

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 206361

Name: PEGGY DAVIS

Address: 120 ROGERS LN

BLAIRSVILLE GA 30512

Date: 9/17/26

T/L 250AG W/200G @2.499 ALL LINES THERE
CALL 404-316-6937 CUSTOMER PAYING BY CK-SLM

Order #: 545756

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Furnace	Furnace	W/H			
Manufacturer	Tran	Tran	Bradford			
Model #	NV	NV	MITW5046CX12			
Serial #	NV	NV	WD9241920			
Burner/Combustion Chamber	☒ Ok	☒ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☒ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☒ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
250	M2428007	Good	Trane	2024	AC	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	Rego	LV3403TR9	2/26	☒ Correct ☐ Incorrect	
2nd	Rego	4403	NV	☒ Correct ☐ Incorrect	11.2

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
100 PSI	100 PSI	10 Mins	☒ Yes	_____ PSI	_____ PSI	_____ Mins	☐ Yes
_____ WC	_____ WC	_____ Mins	☐ No				☐ No

Comments:

Customer Acknowledgment:

I acknowledge, by checking each of the following items, that:

- ☒ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☒ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☒ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☒ I have smelled propane gas and can detect its odor.
- ☒ I have been told to consider installing one or more gas detectors.
- ☒ I have received safety information and told to read it and share it with all family members.
- ☒ I am satisfied with the service work performed.

Service Technician (Print)	Fernando Sorde	Service Technician (Signature)	[Signature]	Date	9/17/26
Customer (Print)	PEGGY DAVIS	Customer (Signature)	[Signature]	Date	



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 206361
Name PEGGY DAVIS
Address 120 ROGERS LN BLAIRSVILLE GA 30512

Date: 9/17/26
Instructions: T/I 250AG W/200G @2.499 ALL LINES
THERE CALL 404-316-6937 CUSTOMER PAYING BY CK
ON SITE SLM
Order #: 545756

DESCRIPTION OF WORK
COMMENTS:
SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY			
Performed leak check	Yes	No	
Gas check attached	Yes	No	
Leak check	Initial		
Start Pressure	End Pressure	Time Held	System OK

% in Tank

AMOUNT REC'D
\$
☐ CASH ☐ CHECK #
☐ CREDIT CARD
#
EXP. DATE
* I have received the Consumer Safety information & material. * I am satisfied with the work performed. * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment. * Signing agrees to _____ year contract for discount.
CUSTOMER SIGNATURE

Retail Price	Contract Price	
Rinnai \$	\$	
Standard Vent Kit \$	\$	
Standard Install \$	\$	
Total \$	\$	
Tank Set	New Cust Special	
L.P. Gas /Gal 2.999	L.P. Gas /Gal 2.499	
Gallons 200	Gallons 200	
FRCC \$9.79	FRCC \$9.79	9.79
Fuel Total 599.80	Fuel Total 499.80	499.80
Tank Lease/Yr 99.00	1st yr Lease FREE	FREE
Total Materials		
Sub-Total		
Sales Tax		
Tank Set Fee \$250	Tank Set Fee 20.00	20.00
Safety Inspection \$129.95	\$29.95	29.95
Total Labor		
Total charges		
Prepay Bal On Account		
Safe Appliance Savings		529.00
Safe Appliance Rebate		100.00
TOTAL BALANCE DUE		