

✓ Sum

2

9/18/2026 3:52:31 PM

WORK ORDER

Renee Lake

156 OVERLAKE COURT
MORGANTON, GA 30560
(678) 699-3432

Customer #: 21455
Order #: 546234
Location #: 245680
Zone: B-012-FRI-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 9/23/26 Hook up stove conversion kit on site. Hook up regulator on site to the cooktop. Call 706-889-8553 Invoice Apex Performance @ApexperformanceLLC.com-SLM

Date Ordered: 9/18/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
-------------------------	-----------------	------------------	--------	-------

Name: Heating System	Last Service: 9/17/2026	Last Tune Up:
Contract:	SC Renewal:	
Manufact:	Model:	
Notes:		
Instructions:		

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 21455

Name: RENEE LAKE

Address: 156 OVERLAKE CT

MORGANTON GA 30560

Date: 9/23/26

Instructions: HOOK UP STOVE CONVERSION KIT ON SITE
HOOK UP REGULATOR TO COOKTOP REGULATOR ON SITE
CALL 706-889-8553 INVOICE APEX PERFORMANCE-SLM

Order #: 245680

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Cook Top					
Manufacturer	Kitchen Aid					
Model #	KUGCT06SS02					
Serial #	DE0902981					
Burner/Combustion Chamber	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
500	~~M0803853~~ M0803853	good	Thiarc	~~2008~~ 2008	UG	good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	Sherwood	NA	☒ Correct ☐ Incorrect		
2nd	Sherwood	NA	☒ Correct ☐ Incorrect	11.2	13.8

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
120 PSI	120 PSI	10 Mins	☒ Yes	____ PSI	____ PSI	____ Mins	☐ Yes
____ WC	____ WC	____ Mins	☐ No				☐ No

Comments:

Customer Acknowledgment:

 I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print) <u>Brandon Payne</u>	Service Technician (Signature) <u>Brandon Payne</u>	Date
Customer (Print)	Customer (Signature)	Date



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 21455

Name RENEE LAKEE

Address 156 OVERLAKEE CT

MORGANTON GA 30560

Date: 7-31-25

Instructions T/I 120 W/100G @ 3.599 RUN LINES TO GRILL AND GRIDDLEE NEED CUTOFFS JERMEY HOWARD

Order #: 706-889-8553 BILL APEX

38110 ~~381105~~

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check Yes No

Gas check attached Yes No

Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

#

EXP. DATE

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to year contract for discount.

CUSTOMER SIGNATURE

Retail Price

Contract Price

Rinnai	\$	\$
Standard Vent Kit	\$	\$
Standard Install	\$	\$
Total	\$	\$

Tank Set

New Cust Special

L P Gas /Gal	3.599	L P Gas /Gal	3.599
Gallons	100	Gallons	100
FRCC	\$9.79	FRCC	\$9.79
Fuel Total	359.90	Fuel Total	359.90
Tank Lease/YR	99.00	1st yr Lease	99.00
Total Materials			
Sub-Total			
Sales Tax			
Tank Set Fee	\$250	Tank Set Fee	
Safety Inspection	\$129.95		\$29.95
Total Labor			
Total charges			
Prepay Bal On Account			

Safe Appliance Savings 350.00

Safe Appliance Rebate 50.00

TOTAL BALANCE DUE