

CK # 235
\$1745.34

✓ Sum

9/18/2026 9:59:34 AM

WORK ORDER

Frank Crosier

100 Redridge Road
Morganton, GA 30560
(812) 972-2030

Customer #: 206634
Order #: 546130
Location #: 282943
Zone: B-013-FRI-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 9/21/26 T/I 30" Super Sass VF SR T/I on/off remote. Lines there
Call 812-972-2030 COD-SLM

Date Ordered: 9/18/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
--------------------------------	------------------------	-------------------------	---------------	--------------

Name:

Last Service: 9/9/2026

Last Tune Up:

Contract:

SC Renewal:

Manufact:

Model:

Notes:

Instructions:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 206634

Name: FRANK CROSLER

Address: 100 REDRIDGE RD
MORGANTON GA 30560

Date: 9/21/26

Instructions: T/I 30" SUPER SASS VFSR T/I ON/OFF
REMOTE. LINES THERE CALL 812-972-2030
COD-SLM

Order #: 546130

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	FP		Cook Top			
Manufacturer	Empire		Kitchenaid			
Model #	VFSR-30-4		KS65530SP30			
Serial #	2622P487681		RF0718249			
Burner/Combustion Chamber	☒ Ok	☐ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☐ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☐ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
120	M2605111	Good	Triarc	2026	AC6	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin	Rogo	8/20	☒ Correct ☐ Incorrect	11.2	13.1
1st			☐ Correct ☐ Incorrect		
2nd			☐ Correct ☐ Incorrect		

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
120 PSI	120 PSI	10 Mins	☒ Yes	_____ PSI	_____ PSI	_____ Mins	☐ Yes
_____ WC	_____ WC	_____ Mins	☐ No				☐ No

Comments:

Customer Acknowledgment:

 I acknowledge, by checking each of the following items, that:

- ☒ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☒ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☒ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☒ I have smelled propane gas and can detect its odor.
- ☒ I have been told to consider installing one or more gas detectors.
- ☒ I have received safety information and told to read it and share it with all family members.
- ☒ I am satisfied with the service work performed.

Service Technician (Print) Fernando Sordo	Service Technician (Signature) 	Date 9/21/26
Customer (Print)	Customer (Signature) 	Date



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 206634

Name FRANK CROSIER

Address 100 REDRIDGE RD
MORGANTON GA 30560

Date: 9/9/26

Instructions: T/I 120 W/100G @3.599 LINES ARE
THERE SET TANK AS CLOSE TO HOUSE AS POSSIBLE
CUSTOMER WILL MARK WHERE TANK TO GO CALL

Order #: 543422 812-972-2030 CCOF-CLT

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check Yes No

Gas check attached Yes No

Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

#

EXP. DATE

* I have received the Consumer Safety information & material.

* I am satisfied with the work performed.

* Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.

* Signing agrees to year contract for discount.

CUSTOMER SIGNATURE

Retail Price

Rinnai \$

Standard Vent Kit \$

Standard Install \$

Total \$

Contract Price

\$

\$

\$

\$

Tank Set

L P Gas /Gal 3.599

Gallons 100

FRCC \$9.79

Fuel Total 359.90

Tank Lease/YR 99.00

Total Materials

Sub-Total

Sales Tax

Tank Set Fee \$250

Safety Inspection \$129.95

Total Labor

Total charges

Prepay Bal On Account

New Cust Special

L P Gas /Gal 3.599

Gallons 100

FRCC \$9.79

Fuel Total 359.90

1st yr Lease 99.00

Tank Set Fee FREE

Safety Inspection \$29.95

Safe Appliance Savings

350.00

Safe Appliance Rebate 50.00

TOTAL BALANCE DUE