

✓ VSLM

9/18/2026 11:50:09 AM

WORK ORDER

David Holland

125 Old Bend Rd
Blue Ridge, GA 30513
(912) 266-1846

Customer #: 205805
Order #: 546152
Location #: 281872
Zone: B-005-TUE-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 9/21/26 Hook lines to regulator on house. Call 912-266-1846
CCOF-SLM

Date Ordered: 9/18/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
-------------------------	-----------------	------------------	--------	-------

Name:	Last Service: 9/17/2026	Last Tune Up:
Contract:	SC Renewal:	
Manufact:	Model:	
Notes:		
Instructions:		

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 205805

Name: DAVID HOLLAND

Address: 125 OLD BEND RD

BLUE RIDGE GA 30513

Date: 9/21/26

Instructions: HOOK LINES TO REGULATOR ON HOUSE
CALL 912-266-1846 CCOF-SLM

Order #: 546152

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	~~by set~~	Water heater	Stove		
Manufacturer		Rinnai	Kitchenaid		
Model #		RX161	RFD0948SS00		
Serial #		TA.BA-015962	DF0802736		
Burner/Combustion Chamber	☐ Ok	☒ Ok	☒ Ok	☐ Ok	☐ Ok
Manual Shutoff	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☐ Ok	☒ Ok	☒ Ok	☐ Ok	☐ Ok
Pilot Safety System	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☐ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☐ Ok	☒ Ok	☒ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☐ No	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
325	M2605053	Good	Triarc	2026	U.G.	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	Recp	LV3403TR902-2026	☒ Correct ☐ Incorrect		
2nd	MFC	MEGR-122208-2025	☒ Correct ☐ Incorrect	11.5	13.8

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
100 PSI	100 PSI	10 Mins	☒ Yes	15 PSI	15 PSI	10 Mins	☒ Yes
WC	WC	Mins	☐ No				☐ No

Comments:

Customer Acknowledgment:

I acknowledge, by checking each of the following items, that:

- ☒ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☒ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☒ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☒ I have smelled propane gas and can detect its odor.
- ☒ I have been told to consider installing one or more gas detectors.
- ☒ I have received safety information and told to read it and share it with all family members.
- ☒ I am satisfied with the service work performed.

Service Technician (Print)	Branden Payne	Service Technician (Signature)	Branden Payne	Date	9-21-26
Customer (Print)	David Holland	Customer (Signature)	David Holland	Date	



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 205805
Name DAVID HOLLAND
Address 125 OLD BEND RD
BLUE RIDGE GA 30513

Date: 8-21-26
Instructions: DROP 325 W/ 25G @2.499 THEY WILL BURY
ONE ANODE BAG GO TO BACK OF HOUSE BETWEEN HOUSE
AND CREEK. 912-266-1846
Order #: 536249

DESCRIPTION OF WORK
COMMENTS:
SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY	
Performed leak check	Yes ____ No ____
Gas check attached	Yes ____ No ____
Leak check	Initial ____
Start Pressure	End Pressure
Time Held	System OK

% in Tank

AMOUNT REC'D
\$
☐ CASH ☐ CHECK #
☐ CREDIT CARD
#
EXP. DATE
* I have received the Consumer Safety information & material.
* I am satisfied with the work performed.
* Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
* Signing agrees to _____ year contract for discount.
CUSTOMER SIGNATURE

Retail Price		Contract Price
Rinnai	\$	\$
Standard Vent Kit	\$	\$
Standard Install	\$	\$
Total	\$	\$
Tank Set		New Cust Special
L.P. Gas /Gal	2.999	L.P. Gas /Gal 2.499
Gallons	25	Gallons 25
FRCC	\$9.79	FRCC \$9.79
Fuel Total	74.58	Fuel Total 62.48
Tank Lease/YR	129.00	1st yr Lease FREE
Total Materials		
Sub-Total		
Sales Tax		
Tank Set Fee	\$250	Tank Set Fee 20.00
Safety Inspection	\$129.95	\$29.95
Total Labor		
Total charges		
Prepay Bal On Account		
Safe Appliance Savings		479.30
Safe Appliance Rebate		250.00
TOTAL BALANCE DUE		