

15m

C

9/23/2026 10:30:39 AM

WORK ORDER

Robert Dorsey

790 Gaults Gulch Road
Talking Rock, GA 30175
(770) 265-3880

Customer #: 202346
Order #: 546929
Location #: 277630
Zone: B-031-MON-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 9-25-26 Connect line to house already there and test line.
770-265-3880 CCOF SM

Date Ordered: 9/23/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
Name:	Last Service: 4/21/2026	Last Tune Up:		
Contract:	SC Renewal:			
Manufact:	Model:			
Notes:				
Instructions:				

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 202346

Date: 9-24-26

Name: ROBERT DORSEY

Instructions: CONNECT LINE TO HOUSE ALREADY THERE.
TEST LIN CCOF SM 770-265-3880

Address: 790 GAULTS GULCH RD
TALKING ROCK GA 30175

Order #: 546929

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Loglighter	Cooktop	Furnace	W/H		
Manufacturer	NV	CAFE	Goodman	Navien		
Model #	NV	CEU366P21251	CAPEA43303AA	NPE-240A2		
Serial #	NV	LD901209P	2602275217	208702636309F35		
Burner/Combustion Chamber	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
325	M2327898	Good	Triarc	2023	UC	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	Riso	3-24	☒ Correct ☐ Incorrect		
2nd	MEE	may-26	☒ Correct ☐ Incorrect	11.6	12.7

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
110 PSI	110 PSI	10 Mins	☒ Yes	15 PSI	15 PSI	10 Mins	☒ Yes
WC	WC	Mins	☐ No				☐ No

Comments:

Customer Acknowledgment:

 I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	Service Technician (Signature)	Date
Alan Wren	[Signature]	9-24-26
Customer (Print)	Customer (Signature)	Date
Robert Dorsey	[Signature]	



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 202346

Name Robert Dorsey

Address 790 Gaults Gulch Road

Talking Rock, GA 30175

Date: 10/22/2024

Instructions: Go 1st! Johnny to bury; T/I 325UG
w/260gal @2.999; T/I Monitor - Going on Auto;
Run yard line to generator & hook up; Robert
(770)265-3880; COD

Order #: 25582

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check ☐ Yes ☐ No

Gas check attached ☐ Yes ☐ No

Leak check Initial ☐

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

#

EXP. DATE

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed.
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to _____ year contract for discount.

CUSTOMER SIGNATURE

Retail Price		Contract Price	
Rinnai	\$	\$	
Standard Vent Kit	\$	\$	
Standard Install	\$	\$	
Total	\$	\$	
Tank Set		New Cust Special	
L P Gas /Gal	3.299	L P Gas /Gal	2.999
Gallons	260	Gallons	260
FRCC	\$9.79	FRCC	\$9.79
Fuel Total	857.74	Fuel Total	779.74
Tank Lease/YR	129.00	1st yr Lease	FREE
Total Materials			
Sub-Total			
Sales Tax			
Tank Set Fee	\$250	Tank Set Fee	20.00
Safety Inspection	\$129.95		\$29.95
Total Labor			
Total charges			
Prepay Bal On Account			
Safe Appliance Savings			551.49
Safe Appliance Rebate			600.00
TOTAL BALANCE DUE			