



INVOICE

NO 11453 ✓

HOME OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

NAME	<u>Perry White Migrant house 243</u>	ACCOUNT NO.	
MAIL ADDRESS	<u>2453 County Farm Rd</u>	DATE ORDERED	
CITY/STATE/ZIP	<u>Baxley GA 31513</u>	DATE PROMISED	
PHONE	<u>912-347-3140</u>	DATE COMPLETED	<u>8-12-26</u>
LOCATION		TERMS	

INSTRUCTIONS

QTY.	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
4	Rinnai tankless water heater #RE 1990 w/ isolation valves Serial # WE.4A-057624 # TL.4A-164972 # WE.4A-057622 # WE.4A-052984	1500 00	6000 00

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐

SERVICES PERFORMED

installed 4 tankless water heaters

TOTAL MATERIAL

TOTAL TIME _____ HOURS LABOR

THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.

SERVICES PERFORMED

BY Do. H. H.

SUBTOTAL

SALES TAX

TOTAL DUE 6000 00

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

INSTALLATION OR TURN ON	REMOVAL OR TURN OFF	LEAK AND PRESSURE TEST	
		HIGH	LOW
SIZE:	SIZE	START LOCK UP:	START LOCK UP:
S/N:	S/N:	TANK OFF PRESSURE:	TANK OFF PRESSURE:
GALLONS OR READING:	GALLONS OR READING:	AFTER 10 MINUTES PRESSURE AS LEFT:	AFTER 10 MINUTES PRESSURE AS LEFT:

-6000 rebate 800.00
AMOUNT
RECEIVED \$ 5200.00RECEIVED BY Do. H. H.

DATE

SERVICES RECEIVED BY

GASCheck - Gas Appliance System Check

Account Name _____ Invoice Number _____ Date 9 / 29 / 26
 Name Perry White Migrant House 2+3 Company Sikes Propane, Inc.
 Address 5483 Crosby Chapel Ch. Rd. Call Taken By _____
 City Baxley State GA Zip 31513 Telephone (Cell) 912-247-3140 (Home) _____

Appliance Check

Appliance	Water heater	Water heater	Water heater	Water heater	cooktop
Manufacturer	Rinnai	Rinnai	Rinnai	Rinnai	Dali-kit
Model #	RE199a	RE199a	RE199a	RE199a	DK257-A10
Serial #	WE.4A-05 7624	TL.4A-16 4972	WE.4A-05 7622	WE.4A-05 2984	N/A
BTU's	199,000	199,000	199,000	199,000	N/A
Burner / Com. Chamber	ok	ok	ok	ok	ok
Man. Shutoff / Sed. Trap	installed	installed	installed	installed	installed
Control / Pilot Safety System	ok	ok	ok	ok	ok
Venting System	ok	ok	ok	ok	ok
Age	new	new	new	new	new
Taken Out Of Service Or Operation					(X20)

Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
250	1549015	Quality Steel	2025	ok	new	03C23	ok

Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held
135psi.	135psi.	10min.	0
			Work Order 0

Piping Check

Materials	Size	Cover / Protection
coated copper	1/2"	ok

System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held
9in.wc.	9in.wc.	10min	0
			Work Order 0

Regulator Check

Type	Manufacturer	Date / Model	Vent Position / Protection
First	Rego	06C2025 / LV4403TR9	u-c
Second	Rego	08B2024 / LV4403B66	down
Second	Rego	08B2025 / LV4403B66	down

Safety Information Supplied:

Comments: Please note all repairs and corrections made along with any recommended actions.