



INVOICE

No 11502

HOME OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

NAME	<u>Selena & Jessie Weaver</u>	ACCOUNT NO.	
MAIL ADDRESS	<u>465 Gilbert Lane</u>	DATE ORDERED	
CITY/STATE/ZIP	<u>Baxley GA 31513</u>	DATE PROMISED	
PHONE	<u>912-240-0033</u>	DATE COMPLETED	<u>10-1-26</u>
LOCATION		TERMS	

INSTRUCTIONS set 120 gallon tank, install gas range

QTY	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
1	30" Frigidaire FCRG3062 ASM gas range		899 95
100	gallon of propane	2 99	299 00
22'	3/8" coated copper tubing	3 29	72 38
1	3/8" cut off valve	12 95	12 95
4	3/8" flange nut	1 80	7 20
1	3/8" x 1/2" male adapter	2 89	2 89

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER: 1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐ 2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐ THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME. X _____ CUSTOMER'S SIGNATURE	SERVICES PERFORMED <u>set 120 gallon tank,</u> <u>installed gas range & converted to LP,</u> <u>ran gas line & pressure check, lit &</u> <u>checked out range</u>	TOTAL MATERIAL	1294 37
	TOTAL TIME _____ HOURS	LABOR	250 00
	BY <u>Dan Sikes</u>	SUBTOTAL	
		SALES TAX	103 55
		TOTAL DUE	1647 92

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE				- GPGA rebate 50.00 AMOUNT \$ 1597.92
INSTALLATION OR TURN ON	REMOVAL OR TURN OFF	LEAK AND PRESSURE TEST		
		HIGH	LOW	
SIZE <u>120</u>	SIZE	START LOCK UP:	START LOCK UP:	RECEIVED BY _____
S/N: <u>1A75988</u>	S/N:	TANK OFF PRESSURE:	TANK OFF PRESSURE:	DATE _____
GALLONS OR READING: <u>100 gal</u>	GALLONS OR READING:	AFTER 10 MINUTES:	AFTER 10 MINUTES:	SERVICES RECEIVED BY _____
		PRESSURE AS LEFT:	PRESSURE AS LEFT:	

GASCheck - Gas Appliance System Check

Account Name _____ Invoice Number _____ Date 10/1/26
 Name Selena + Jessie Weaver Company Sikes Propane, Inc.
 Address 465 Gilbert Lane Call Taken By _____
 City Baxley State GA Zip 31513 Telephone (Cell) 912-240-0033 (Home) _____

Appliance Check

Appliance	<u>Range</u>					
Manufacturer	<u>Frigidaire</u>					
Model #	<u>FCRG3062</u>					
Serial #	<u>ASM</u> <u>VF634571</u> <u>35</u>					
BTL's	<u>74,000</u>					
Burner / Com. Chamber	<u>ok</u>					
Man. Shutoff - Sed. Trap	<u>installed</u>					
Control / Pilot Safety System	<u>ok</u>					
Venting System	<u>ok</u>					
Age	<u>new</u>					
Taken Out Of Service Or Operation						

Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
<u>120</u>	<u>1A75988</u>	<u>American W.</u>	<u>1986</u>	<u>ok</u>	<u>ok</u>	<u>2A24</u>	<u>ok</u>

Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held
<u>120 psi.</u>	<u>120 psi.</u>	<u>10 min.</u>	<u>0</u>
			<u>0</u>
			<u>0</u>

Piping Check

Materials	Size	Cover / Protection
<u>coated copper</u>	<u>3/8"</u>	<u>ok</u>

System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held
<u>9 in. wc.</u>	<u>9 in. wc.</u>	<u>10 min.</u>	<u>0</u>
			<u>0</u>
			<u>0</u>

Regulator Check

Type	Manufacturer	Date / Model	Vent Position / Protection
<u>Twin</u>	<u>Rago</u>	<u>09C2024 / LV404B39</u>	<u>u-c</u>

Safety Information Supplied:

Comments: Please note all repairs and corrections made along with any recommended actions