

✓ sum

9/28/2026 9:21:56 AM

WORK ORDER

Joseph Ward

642 Wilderness Way
Blairsville, GA 30512
(770) 546-2704

Customer #: 204445
Order #: 547655
Location #: 280220
Zone: B-017-MON-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 9/30/26 Connect stove top thats on site conversion kit is here
Call 352-464-4902 Email invoice to
payables@timberlakecustomhomes.com

Date Ordered: 9/28/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
-------------------------	-----------------	------------------	--------	-------

Name:

Last Service: 9/18/2026

Last Tune Up:

Contract:

SC Renewal:

Manufact:

Model:

Notes:

Instructions:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 204445

Date: 9/30/26

Name: JOSEPH WARD

Instructions: CONNECT STOVE TOP THATS ON SITE TAKE

Address: 642 WILDERNESS WAY

CONVERSION KIT CALL 352-464-4902 EMAIL INVOICE

BLAIRSVILLE, GA 30512

Order #: 547644

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Stove Top					
Manufacturer	Wolf					
Model #	CE152TF/S					
Serial #	18717273					
Burner/Combustion Chamber	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
1000	069411	Good	American	2025	GA	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	MER	1222H	3-5-14-25	☒ Correct ☐ Incorrect	
2nd	REGO	4403B46	5-25	☒ Correct ☐ Incorrect	11.4

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
50 PSI	50 PSI	10 Mins	☒ Yes				☐ Yes
			☐ No				☐ No

Comments:

Customer Acknowledgment:

I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	Service Technician (Signature)	Date
Arin Wilson	[Signature]	9-30-26
Customer (Print)	Customer (Signature)	Date
	Customer not present	



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 204445
Name JOSEPH WARD
Address 642 WILDERNESS WAY
BLAIRSVILLE GA 30512

Date: 9-23-26
Instructions: T/I250 W/ 200G @ 2.499 RUN YARD
LINE. CONNECT TO HOUSE. CCOF 352-464-4902
Order #: 547435

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check Yes No

Gas check attached Yes No

Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

#

EXP. DATE

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed.
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to year contract for discount.

CUSTOMER SIGNATURE

Retail Price

Contract Price

Rinnai \$

\$

Standard Vent Kit \$

\$

Standard Install \$

\$

Total \$

\$

Tank Set

New Cust Special

L.P. Gas /Gal 2.999

L.P. Gas /Gal 2.499

Gallons 200

Gallons 200

FRCC \$9.79

FRCC \$9.79

9.79

Fuel Total 599.80

Fuel Total 499.80

499.80

Tank Lease/YR 99.00

1st yr Lease FREE

FREE

Total Materials

Sub-Total

Sales Tax

Tank Set Fee \$250

Tank Set Fee 20.00

20.00

Safety Inspection \$129.95

\$29.95

29.95

Total Labor

Total charges

Prepay Bal On Account

Safe Appliance Savings

529.00

Safe Appliance Rebate 50.00

TOTAL BALANCE DUE